

Architect's Supplemental Instructions

Architect's Project No:
04561.01

Architect's ASI No: 068R

Project:
Webster University
Interdisciplinary Science
Building

Date Issued: 05/27/2017

Contract Date:

Reason Code: 05 A/E Scope

Discipline Code: 11 (Plumbing)

Owner:
Webster University

Architect:
Cannon Design
1100 Clark Avenue
St. Louis, MO 63102

Contractor:
Paric Construction

Contract For: General construction

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Indicate your acceptance of these instructions for minor change to the Work as consistent with the Contract Documents and return a copy to the Architect within fourteen (14) business days of the date of issuance of these instructions. If you feel a change in Contract Sum or Contract Time is warranted, please submit an itemized quotation for the changes for approval within fourteen (14) business days of the date of issuance of these instructions prior to proceeding on the Work. Proceeding with the Work in accordance with these instructions indicates your acknowledgement that there will be no change.

Attachments:

None

Description: ASI – 065

Reason Codes:
#1. Jurisdictional Agency
#2. Constructor Driven
#3. Document Inconsistency
#4. Fast Track Driven
#5. A/E Scope
#6. Owners Scope
#7. Unforeseeable Conditions
#8. Other

Discipline Codes
#1. Demo-demolition
#2. Div1-Division 1 items on the spec book
(this item is not used)
#3. Electrical
#4. Elevator
#5. Equipment (Changes in equipment,
Owner Purchased)
#6. Fire Protection

Discipline Codes
#7. General Construction (Architectural)
#8. General Conditions (Div. 1)
#9. HVAC
#10. Other
#11. Plumbing
#12. Site Work/Landscaping
#13. Structural

St. Louis
Baltimore
Boston
Buffalo
Calgary
Chicago
Houston
Los Angeles
Mumbai
New York
Phoenix
San Francisco
Shanghai
Toronto
Vancouver
Victoria
Washington DC

1100 Clark Avenue
St. Louis, Missouri
63102
T: 314.241.6250
F: 314.241.2570
www.cannondesign.com

Architect's Supplemental Instructions

Page 2

ASI-068 is being issued for the purpose of replacing the faucet aerator for the following fixtures:

1. SK-1 – Chicago Faucet model 200-AABCP.
Provide Chicago Faucet model E38JKABCP, 0.35 gpm aerator.
2. LAV-1 – Symmons faucet model S-20-2-G-0.5.
Provide Symmons model FLR-01743 0, .35 gpm male aerator.
3. LAV-2 - Symmons faucet model S-20-2-G-0.5.
Provide Symmons model FLR-01743 0, .35 gpm male aerator.

Aerators removed shall be package, identified for fixture/use and returned to the owner.

Please submit an itemized proposal for changes in contract Sum and Contract Time for proposed modifications to the Contract Documents described herein:

**Issued by Architect: Michael R. Whitworth
Webb engineering Services, Inc.**

Accepted by Contractor:
