

THE SEAL(S) AND SIGNATURE(S) APPLY ONLY TO THE DOCUMENT TO WHICH THEY ARE AFFIXED, AND EXPRESSLY DISCLAIM ANY RESPONSIBILITY FOR ALL OTHER PLANS, SPECIFICATIONS, ESTIMATES, REPORTS OR OTHER DOCUMENTS OR INSTRUMENTS RELATING TO OR INTENDED TO BE USED FOR ANY PART OR PARTS OF THE ARCHITECTURAL OR ENGINEERING PROJECT.



Webster University
Interdisciplinary Science
Building

CANNONDESIGN

1100 Clark Avenue
St. Louis, Missouri 63102
T: 314.241.6250
F: 314.241.2570

William Tao & Associates, Inc.
MERFP Engineer
7955 Manchester Road, Suite 125
St. Louis, MO 63143
314.864.7600

David Mason & Associates, Inc.
Structural & Civil Engineer
800 South Vandeventer Avenue
St. Louis, MO 63110
314.534.1053

Faith Group
Technology
3101 S. Hanley Rd., Suite 100
St. Louis, MO 63143
314.591.2229

Kuhnmann Leavitt, Inc.
Environmental Graphics & Signage
7400 Pershing Ave.
St. Louis, MO 63130
314.725.6616

KWA Architects
Architecture
3721 Litzinger Road
St. Louis, MO 63124
314.962.2560

Spellman Brady & Company
Interior Designer
8251 Maryland Avenue, Suite 300
St. Louis, MO 63105
314.862.0070

SWT Design
Landscape Architect
7722 Briar Bend Blvd
St. Louis, MO 63119
314.644.5700

Webb Engineering Services, Inc.
Plumbing & Fire Protection
1400 S. 3rd Street, Suite 201
St. Louis, MO 63104
314.558.0600

2 ADDENDUM 2-2 19 APRIL 2016
1 ADDENDUM 2-1 17 MAR 2016
- ISSUED FOR CONSTRUCTION (BP2) 01 MAR 2016

No.	Description	Date
-----	-------------	------

Drawing Title:

PANEL SCHEDULES

Project No.: 04561.01

Checked by:

E0505

© Cannon Design 2015

Panel: 2LL4

Location: CORR-1 C280-1
Supply From: SB-2
Mounting: S
Enclosure: Type 1

Volts: 120/208 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10,000
Main Type: MCB
Mains Rating: 225 A
MCB Rating:

CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT
1	Science Classroom 276 - Surface Raceway	20 A	1	360	360			1	20 A Microscopy Room 274 - Surface Raceway	2
3	Science Classroom 276 - Surface Raceway	20 A	1		360	360		1	20 A Microscopy Room 274 - Surface Raceway	4
5	Science Classroom 276 - Fume Hood	20 A	1			180	360	1	20 A Microscopy Room 274 - Surface Raceway	6
7	Science Classroom 276 - Surface Raceway	20 A	1	360	360			1	20 A Microscopy Room 274 - Surface Raceway	8
9	Science Classroom 276 - Surface Raceway	20 A	1		360	180		1	20 A Microscopy Room 274 - Surface Raceway	10
11	Science Classroom 276 - Surface Raceway	20 A	1			180	540	1	20 A Lab Storage 272B - Surface Raceway	12
13	Science Classroom 276 - Teacher	20 A	1	720	360			1	20 A Lab Storage 272B - Surface Raceway	14
15	Science Classroom 276 - Projector	20 A	1		500	540		1	20 A Lab Stor 272B / Chem Stock Rm 272A - ...	16
17	Science Classroom 276 - A/V Cabinet	20 A	1			360	0	1	20 A Spare	18
19	Science Classroom 276 - Desk	20 A	1	360	0			1	20 A Spare	20
21	Science Classroom 276 - Desk	20 A	1		360	0		1	20 A Spare	22
23	Science Classroom 276 - Desk	20 A	1			360	0	1	20 A Spare	24
25	Science Classroom 276 - Desk	20 A	1	360	0			1	20 A Spare	26
27	Science Classroom 276 - Desk	20 A	1		360	0		1	20 A Spare	28
29	Science Classroom 276 - Desk	20 A	1			360	0	1	20 A Spare	30
31	Science Classroom 276 - Shades	20 A	1	540	0			1	20 A Spare	32
33	Science Classroom 276 - Plant Growth lamp	20 A	1		180	0		1	20 A Spare	34
35	Spare	20 A	1			0	0	1	20 A Spare	36
37	Spare	20 A	1	0	0			1	20 A Spare	38
39	Spare	20 A	1		0	0		1	20 A Spare	40
41	Spare	20 A	1			0	0	1	20 A Spare	42
Total Load:				3780 VA	3200 VA	2340 VA				
Total Amps:				33 A	28 A	20 A				

Notes:

Panel: 2LL3

Location: CORR-2 C280-2
Supply From: SB-2
Mounting: S
Enclosure: Type 1

Volts: 120/208 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10,000
Main Type: MCB/SFL
Mains Rating: 225 A
MCB Rating:

CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT
1	Physics Lab 284 - Surface Raceway	20 A	1	540	360			1	20 A Phys Research Lab 282 - Surface Raceway	2
3	Physics Lab 284 - Surface Raceway	20 A	1		540	360		1	20 A Phys Research Lab 282 - Surface Raceway	4
5	Physics Lab 284 - Surface Raceway	20 A	1			540	360	1	20 A Phys Research Lab 282 - Surface Raceway	6
7	Physics Lab 284 - Surface Raceway	20 A	1	540	360			1	20 A Phys Research Lab 282 - Surface Raceway	8
9	Physics Lab 284 - Surface Raceway	20 A	1		540	180		1	20 A Phys Research Lab 282 - Surface Raceway	10
11	Physics Lab 284 - Surface Raceway	20 A	1			360	360	1	20 A Phys Lab Prep 282 - Receptacle	12
13	Physics Lab 284 - Teacher	20 A	1	720	360			1	20 A Phys Lab Prep 282 - Surface Raceway	14
15	Physics Lab 284 - Projector	20 A	1		500	360		1	20 A Phys Lab Prep 282 - Surface Raceway	16
17	Physics Lab 284 - A/V Cabinet	20 A	1			360	180	1	20 A Phys Lab Prep 282 - Surface Raceway	18
19	Physics Lab 284 - Desk	20 A	1	360	540			1	20 A Physics Lab 284 - Shades	20
21	Physics Lab 284 - Desk	20 A	1		360	0		1	20 A Spare	22
23	Physics Lab 284 - Desk	20 A	1			360	0	1	20 A Spare	24
25	Physics Lab 284 - Desk	20 A	1	360	0			1	20 A Spare	26
27	Physics Lab 284 - Desk	20 A	1		360	0		1	20 A Spare	28
29	Physics Lab 284 - Desk	20 A	1			360	0	1	20 A Spare	30
31	Physics Lab 284 - Desk	20 A	1	360	0			1	20 A Spare	32
33	Physics Lab 284 - Desk	20 A	1		360	0		1	20 A Spare	34
35	Physics Lab 284 - Desk	20 A	1			360	0	1	20 A Spare	36
37	Physics Lab 284 - Desk	20 A	1	360	0			1	20 A Spare	38
39	Physics Lab 284 - Desk	20 A	1		360	0		1	20 A Spare	40
41	Physics Lab 284 - Desk	20 A	1			360	0	1	20 A Spare	42
Total Load:				4860 VA	3920 VA	3600 VA				
Total Amps:				41 A	33 A	30 A				

Notes:

Panel: 2LL2

Location: CORR-2 C280-2
Supply From: SB-2
Mounting: S
Enclosure: Type 1

Volts: 120/208 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10,000
Main Type: MCB
Mains Rating: 225 A
MCB Rating:

CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT
1	Microbio/Plant Research Lab 283 - Surface...	20 A	1	360	180			1	20 A Microbio/Plant Research Lab 283 - Desk	2
3	Microbio/Plant Research Lab 283 - Surface...	20 A	1		180	180		1	20 A Microbio/Plant Research Lab 283 - Desk	4
5	Microbio/Plant Research Lab 283 - UC Glass...	20 A	1			180	180	1	20 A Microbio/Plant Research Lab 283 - Desk	6
7	Microbio/Plant Research Lab 283 - Fume Hood	20 A	1	500	180			1	20 A Microbio/Plant Research Lab 283 - Desk	8
9	Microbio/Plant Research Lab 283 - Surface...	20 A	1		360	144		1	20 A Microbio/Plant Research Lab 283 - ...	10
11	Microbio/Plant Research Lab 283 - Surface...	20 A	1			360	360	1	20 A Microbio Prep 289A - Surface Raceway	12
13	Microbio/Plant Research Lab 283 - Surface...	20 A	1	360	180			1	20 A Microbio Prep 289A - Surface Raceway	14
15	Microbio/Plant Research Lab 283 - Surface...	20 A	1		360	180		1	20 A Microbio Prep 289A - Receptacle	16
17	Microbio/Plant Research Lab 283 - Surface...	20 A	1			360	1000	1	20 A Microbio Prep 289A - Refrigerator	18
19	Microbio/Plant Research Lab 283 - Surface...	20 A	1	540	0			1	20 A Spare	20
21	Microbio/Plant Research Lab 283 - Microwave	20 A	1		1500	0		1	20 A Spare	22
23	Microbio/Plant Research Lab 283 - Teacher	20 A	1			720	0	1	20 A Spare	24
25	Microbio/Plant Research Lab 283 - Projector	20 A	1	500	0			1	20 A Spare	26
27	Microbio/Plant Research Lab 283 - A/V Cabinet	20 A	1		360	0		1	20 A Spare	28
29	Spare	20 A	1			0	0	1	20 A Spare	30
31	Microbio/Plant Research Lab 283 - Shades	20 A	1	540	0			1	20 A Spare	32
33	Microbio/Plant Research Lab 283 - Desk	20 A	1		180	0		1	20 A Spare	34
35	Microbio/Plant Research Lab 283 - Desk	20 A	1			180	0	1	20 A Spare	36
37	Spare	20 A	1	0	0			1	20 A Spare	38
39	Spare	20 A	1		0	0		1	20 A Spare	40
41	Spare	20 A	1			0	0	1	20 A Spare	42
Total Load:				3340 VA	3444 VA	3340 VA				
Total Amps:				28 A	29 A	28 A				

Notes:

Panel: 3LL1

Location: CORRIDOR-1 C380-1
Supply From: SB-2
Mounting: S
Enclosure: Type 1

Volts: 120/208 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10,000
Main Type: MCB/SFL
Mains Rating: 225 A
MCB Rating:

CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT
1	Anatomy/Physio Lab 391 - Surface Raceway	20 A	1	540	180			1	20 A Bio Lab Prep Room A 389 - Receptacle	2
3	Anatomy/Physio Lab 391 - Surface Raceway	20 A	1		360	180		1	20 A Bio Lab Prep Room A 389 - Receptacle	4
5	Anatomy/Physio Lab 391 - Surface Raceway	20 A	1			360	180	1	20 A Bio Lab Prep Room A 389 - Fume Hood	6
7	Anatomy/Physio Lab 391 - Surface Raceway	20 A	1	180	180			1	20 A Bio Lab Prep Room A 389 - Receptacle	8
9	Anatomy/Physio Lab 391 - Fume Hood	20 A	1		500	360		1	20 A Bio Lab Prep Room A 389 - Surface Raceway	10
11	Anatomy/Physio Lab 391 - Receptacle	20 A	1			180	180	1	20 A Bio Lab Prep Room A 389 - Surface Raceway	12
13	Anatomy/Physio Lab 391 - Teacher	20 A	1	720	180			1	20 A Bio Lab Prep Room A 389 - UC Glass Washer	14
15	Anatomy/Physio Lab 391 - Projector	20 A	1		500	360		1	20 A Bio Lab Prep Room A 389 - Surface Raceway	16
17	Anatomy/Physio Lab 391 - A/V Rack	20 A	1			360	180	1	20 A Bio Lab Prep Room A 389 - Surface Raceway	18
19	Anatomy/Physio Lab 391/389 - Shades	20 A	1	540	1080			1	20 A Bio Lab Prep Room A 389 - Dell Cabinet	20
21	Anatomy/Physio Lab 391 - Desk	20 A	1		360	0		1	20 A Spare	22
23	Anatomy/Physio Lab 391 - Desk	20 A	1			360	0	1	20 A Spare	24
25	Anatomy/Physio Lab 391 - Desk	20 A	1	360	0			1	20 A Spare	26
27	Anatomy/Physio Lab 391 - Desk	20 A	1		360	1700		2	30 A Bio Lab Prep Room A 389 - Sorvall Centrifuge	28
29	Anatomy/Physio Lab 391 - Desk	20 A	1			360	1700	2	30 A Bio Lab Prep Room A 389 - Surface Raceway	30
31	Anatomy/Physio Lab 391 - Desk	20 A	1	360	1700			2	30 A Bio Lab Prep Room A 389 - Ultra Centrifuge	32
33	Anatomy/Physio Lab 391 - Desk	20 A	1		360	1700		2	30 A Bio Lab Prep Room A 389 - Ultra Centrifuge	34
35	Anatomy/Physio Lab 391 - Desk	20 A	1			360	1700	2	30 A Anatomy/Physio Lab 391 - Sorvall Centrifuge	36
37	Anatomy/Physio Lab 391 - Display Case	20 A	1	180	1700			2	30 A Anatomy/Physio Lab 391 - Sorvall Centrifuge	38
39	Spare	20 A	1		0	1700		2	30 A Anatomy/Physio Lab 391 - Ultra Centrifuge	40
41	Spare	20 A	1		8440 VA	7620 VA		2	30 A Anatomy/Physio Lab 391 - Ultra Centrifuge	42
Total Load:				7900 VA	8440 VA	7620 VA				
Total Amps:				66 A	71 A	64 A				

Notes:

Panel: 3NL1

Location: ELEC 310A
Supply From: SB-1
Mounting: S
Enclosure: Type 1

Volts: 120/208 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10,000
Main Type: MCB/SFL
Mains Rating: 225 A
MCB Rating:

CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT	
1	Power Rm. C310, 310A, 312	20 A	1	720 VA/720 VA			1	20 A	Power Rm. 342,344	2	
3	Power Rm. 304, 306	20 A	1		720 VA/720 VA		1	20 A	Power Rm. 344, 346, 348	4	
5	Power Rm. 302, C350A, 303	20 A	1			720 VA/720 VA	1	20 A	Power Rm. 346, 352,354	6	
7	Power Rm. C310, 339	20 A	1	540 VA/360 VA			1	20 A	Power Rm. 352	8	
9	Power Rm. 305	20 A	1		180 VA/360 VA		1	20 A	Power Rm. 352	10	
11	Power Rm. 305, 311	20 A	1			540 VA/720 VA	1	20 A	Power Rm. 356, 360, 362	12	
13	Power Rm. 311, 313, 315	20 A	1	720 VA/360 VA			1	20 A	Power Rm. 362, 364	14	
15	Power Rm. 315, 317, 319	20 A	1		720 VA/180 VA		1	20 A	Work/Copy 300A - Counter	16	
17	Power Rm. 319, 321, 323	20 A	1			720 VA/360 VA	1	20 A	Kettle 300C - Desk	18	
19	Power Rm. 323, 325, 327	20 A	1	720 VA/360 VA			1	20 A	Kettle 300C - Desk	20	
21	Power Rm. 325	20 A	1		180 VA/1000...		1	20 A	Kettle 300C - Refrigerator	22	
23	Power Rm. 327	20 A	1			360 VA/1656...	1	30 A	Kettle 300C - GD-3	24	
25	Power Rm. 327, 329, 331	20 A	1	720 VA/180 VA			1	20 A	Kettle 300C - Counter	26	
27	Power Rm. 331, 333, 335	20 A	1		720 VA/180 VA		1	20 A	Kettle 300C - Counter	28	
29	Power Rm. 335, 337, 339	20 A	1			720 VA/180 VA		2	20 A	Work/ Copy 300A - Printer	30
31	Power Rm. 320, 322	20 A	1	540 VA/180 VA							32
33	Power Rm. 316, 318, 320	20 A	1		720 VA/900 VA				20 A	Jan Closet 375, Corridor C380	34
35	Power Rm. 312, 314	20 A	1			540 VA/370 VA	1	20 A	EW-3	36	
37	Power Rm. 332	20 A	1	540 VA/360 VA			1	20 A	Women 377 - Men 379	38	
39	Power Rm. 332	20 A	1		720 VA/180 VA		1	20 A	Corridor C370 - Digital Signage	40	
41	Power Rm. 332	20 A	1			540 VA/360 VA	1	20 A	Office Lab Mr 372D - Receptacles	42	
43	Data 300B - Wall	20 A	1	180 VA/180 VA			1	20 A	Lab Lab Storage 372C - Autoclave Controls	44	
45	Power Rm. 364	20 A	1		180 VA/180 VA		1	20 A	Lab Storage 372C - C-Counter	46	
47	Power Rm. 302, 303	20 A	1			540 VA/540 VA	1	20 A	Commons C370B, Lab Waste 372B, Lab...	48	
49	Power COMMONS 302	20 A	1	180 VA/720 VA							50
51	Power COMMONS 302	20 A	1		0 VA/360 VA		1	20 A	Power Commons 370B USB Receptacle	52	
53	Spare	20 A	1			0 VA/360 VA	1	20 A	Power Commons 370B USB Receptacle	54	
55	Spare	20 A	1	0 VA/1490...			1	20 A	Men 379 - Electric Hand Dryer	56	
57	Spare	20 A	1		0 VA/1490...		1	20 A	Women 377 - Electric Hand Dryer	58	
59	Spare	20 A	1			0 VA/0 VA	1	20 A	Spare	60	
Total Load:				9770 VA	9690 VA						
Total Amps:				82 A	81 A	83 A					