

© Cannon Design 2015
All rights reserved. No part of this document may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, without written authorization by The Cannon Corporation.
3/30/2016 11:58:48 PM

LAB EQUIPMENT SCHEDULE_LEVEL-1																													
EQUIPMENT ITEM				Count	Mounting Location *	DIMENSIONS			ELECTRICAL				PLUMBING				MECHANICAL				New (N) / Existing (E)	Existing Location	Furnished & Installed by **	Remarks					
Equipment Number	Description	Manufacturer	Model			Floor Offset	Front	Side	Height	Volts	Emergency Power	Amps	Data	Phase	Watts	Floor Drain	Potable Water	DI Water	Gas	Vacuum					Carbon Dioxide	Nitrogen	Compressed Air	Exhaust	Monitoring
133B SIM LAB																													
06.10.01	Anesthesia Machine	GE Datex-Ohmeda	Aespire	1	F	0"	2'-5"	2'-5"	4'-7"	120	15							X	X					X	X	N		Total dimensions include monitors on top; DISS: Diameter Index Safety System; http://www.dremed.com/catalog/product_info.php/products_id/1818	
06.10.02	Adult Spinal/Epidural	Life Form	LF1036	1	S	0"	1'-5"	1'-5"	10"																	E		https://www.simulab.com	
06.10.03	Infant Lumbar Puncture	SimuLab	LPB-10	1	S	0"	1'-0"	1'-1"	1'-8"																	E			
06.10.05	Surg - Instrument Table	Steris	Amsco 3085SP	1	F	0"	6'-4"	1'-10"	3'-0"	100-120		5														N		http://www.venturemedical.com/products/surgical_tables/amsco_surgery_table_-_refurbished_d_model_2080m/	
06.10.06	Surg - Instrument Table	Steris	Amsco 3085SP	1	F	0"	6'-4"	1'-10"	3'-0"	100-120		5														N		http://www.venturemedical.com/products/surgical_tables/steris_amsco_3085sp_surgery_table_refurbished/	
06.10.07	Anesthesia Cart	DR Instruments	DRC630K	1	F	0"	3'-5"	2'-1"	2'-7"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	N		https://www.drinstruments.com/classic-6-drawer-anesthesia-carts-with-key-lock-bigger-drawer-space.html	
06.10.09	OR Lights	Meditek	BERCHTOLD CHROMOPHARE D660 (435-0300-0175)	1	C	6'-0"	2'-0"	2'-0"	2'-0"																	N	OFCI		
06.10.10	Crash Cart	Global	TrippNT 51072	1	F	0"	2'-7"	1'-8"	4'-0"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	N		http://www.globalindustrial.com/p/medical-lab/service-carts/medical-supply-service-carts/6-drawer-procedure-cart-front-locking-20-x-31w-x-48h-cherry-red/infoParam_campaignId=19F8gclid=CISRs2k0cyCFQEcQodqQW4Q	
06.10.14	Time Out Board			1	W	3'-0"	4'-0"	1"	4'-0"																	N		http://www.vitalitymedical.com/v-pole-2-hook-hmr/gclid=CNSB2z0kcyCFQYJaQodqQW4Q	
06.10.15	Portable suction cannister	Amsino	EZE-VAC	1	F	0"	2'-0"	2'-0"	2'-0"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	N		http://receptai.amsino.com	
06.10.16	Simulation Mannequin	CAE Healthcare	HPS-010	1	F	0"	2'-0"	2'-0"	5'-11"	100-220		2.3								X		X	X	X	N		O2, N2O; http://caehealthcare.com/images/uploads/brochures/HPS.pdf		
06.10.17	HPS-Equip Rack	CAE Healthcare	HPS-010	1	F	0"	2'-3"	2'-4"	3'-6 1/2"	100-220												X			N				
12																													
135 DRY SKILLS LAB / COHORT CLASSROOM																													
06.07.34	Virtual Dissection Table	Anatomage		1	F	0"	2'-4"	7'-2"	2'-9"	100-240	10			1150											N		http://www.anatomage.com/images/medical/Videos_TN/AnatomageTableBrochure.pdf		
137																													
MODELS/ ASSESSMENT STORAGE/RESEARCH																													
06.12.01	Ultrasound Cart			4	F	0"	1'-5 1/2"	2'-3"	2'-5"																	N			
06.12.02	Ultrasound Machine	Sonosite	M-turbo	1	B	3'-6"	1'-4"	1'-2"	8"																	E		https://www.sonosite.com/m-turbo	
06.12.03	Ultrasound Machine	Sonosite	M-turbo	3	B	3'-6"	1'-4"	1'-2"	8"	100-240		2														N		https://www.sonosite.com/m-turbo	
06.12.04	Gas Cabinet	Safety Equipment	7200	1	F	0"	2'-0"	1'-6"	6'-3"																	N	OFCI	Spec: 123553; 2-cylinder (2 Oxygen)	
06.12.05	Gas Cabinet	Safety Equipment	7300	1	F	0"	3'-0"	1'-6"	6'-3"																	N	OFCI	Spec: 123553; 3-cylinder (N, N2O, CO2)	
10																													
174 TEACHING KITCHEN																													
10.15.01	6 Range Cooktop	KitchenAid	KGCU467VSS	1	B	2'-10"	2'-11 1/4"	1'-10 1/4"	1'-2"									X								N	OFCI	Specification 113100	
10.15.02	Double Wall Ovens	GE	JK3600SFSS (208v)	1	W	1'-1 1/4"	2'-2 3/4"	1'-11 1/2"	4'-3"	208	30															N	OFCI	Specification 113100	
10.15.03	Hood (with sprinkler system)	CaptiveAir	5430 ND-2	1	W	7'-0"	4'-6"	4'-6"	2'-8"																	N	OFCI	Specification 114000	
10.15.04	Garbage Disposal	InSinkErator	SPACESAVER	1	U	0"	1'-0"	1'-0"	1'-6"								X									N	OFCI	Specification 114000	
10.15.05	Refridgerato/Freezer combo	LG	LFX28968ST	1	F	0"	2'-11 3/4"	2'-11 3/4"	5'-9 3/4"																	N	OFCI	Specification 113100	
10.15.06	Icemaker	Hoshizaki	C-101BAH-AD	1	U	0"	1'-3"	1'-11 3/4"	2'-7 1/2"	115	3.6															N	OFCI	Specification 113100	
10.15.09	Microwave	Dacor	MMDV30S	1	B	1'-4"	2'-6"	1'-11 3/8"	1'-4"	120	15															N	OFCI	Specification 113100	
10.15.10	Commercial Dishwasher	Meiko	FV 40.2 G	1	U	0"	2'-0"	2'-0"	2'-5 1/2"	208	43	2	1													N	OFCI	Specification 114000	
10.15.12	Adjustable Camera			2	C	8'-0"	6"	6"	6"																	N		there were 2 camera. One pointed at the stove and one at the counterop. They could be moved to look elsewhere	
10.15.16	Electronic Mixing Bowl	KitchenAid	KSM150PSER	1	B	2'-10"	9 5/16"	1'-2 5/16"	1'-2"																	N		standard	
10.15.17	Blender	Vitamix	5200	1	B	2'-10"	7 5/16"	8 3/4"	1'-8 1/2"																	N		standard	
12																													
183B CADAVER LAB WORKROOM																													
06.04.02	Incubator-Bench	ThermoScientific	Heracell CO2 with O2 control	1	B	2'-10"	1'-4"	1'-4"	10"																	N		http://www.thermo.fishon.com/CO2/WebProject.asp?BookCode=co211fx&from=2w	
06.04.03	Anesthesia Chamber	Kent Scientific	Sonosuit Small Animal Anesthesia system SOMNO-0710	1	B	2'-10"	2'-1"	1'-8"	1'-8"																	N			
06.04.04	Refrigerator uc			1	U	0"	2'-1"	2'-4"	2'-6"																	N			
06.04.05	CO2 N2 Controller	Biospherix	PROOX21	1	B	2'-10"	8"	4"	8"																	N			
4																													
191 CADAVER LAB																													
06.03.01	Cadaver Table	Mortech Manufacturing	600024	4	F	0"	2'-8"	7'-2"	4'-1"	-												X				N		http://mortechmfg.com/collections/anatomy-dissection-tables/products/hooded-dissection-table-with-exhaust-chamber	
06.03.02	Cadaver Table	Existing		2	F	0"	2'-8"	7'-2"	4'-1"																	E			
06.03.03	Magnifying Light	Mortech Manufacturing	SLMAG	6	F	0"	10"	10"	5'-2"																	N		http://mortechmfg.com/collections/surgical-lighting/products/surgical-light-magnification-stimulag	
06.03.04	Lab Cart	Carolina. Grathell Trolley Storage Cart	705291	6	F	0"	1'-3"	1'-5"	2'-10"	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	N		<a "="" href="http://www.carolina.com/laboratory-carts/stainless-steel-laboratory-cart-300-lb-capacity/705020.pr?question=">http://www.carolina.com/laboratory-carts/stainless-steel-laboratory-cart-300-lb-capacity/705020.pr?question=	
06.03.06	Bone Saw	Mortech	0295-420	4	S	2'-10"	4"	1'-0"	1'-0"	115	8.5															N		http://mortechmfg.com/collections/autopsy-saws-vacuums/products/autopsy-saw-0295-270	
06.03.07	Bone Saw			2	S	2'-10"	2"	1'-0"	1'-0"																	E			
06.03.13	MOBILE LECTERN (Repl w Cswk)			1		0"	2'-1"	2'-1"	3'-4"																		OFCI	Casework	
25																													

GENERAL NOTES:		LEGEND:	
1) ALL THE EQUIPMENT IS "OFO" U.N.O.		* MOUNTING LOCATION: B: Benchtop U: Undercounter F: Floor W: Wall C: Ceiling S: Storage	
		** FURNISHED & INSTALLED BY: OFCI: Contractor Furnishes a Contractor Installed OFCI: Owner Furnishes Contractor Installed OFOI: Owner Furnished Owner Installed	

CONFORMED SET 01 JUL 2016

ISSUED FOR CONSTRUCTION (BP3) 15 MAR 2016	
No.	Description Date

EQUIPMENT LIST
LEVEL-01

Project No.: 04561.01 Checked by:

A1101