

THE SEAL(S) AND SIGNATURE(S) APPLY ONLY TO THE DOCUMENT TO WHICH THEY ARE AFFIXED, AND EXPRESSLY DISCLAIM ANY RESPONSIBILITY FOR ALL OTHER PLANS, SPECIFICATIONS, ESTIMATES, REPORTS OR OTHER DOCUMENTS OR INSTRUMENTS RELATING TO OR INTENDED TO BE USED FOR ANY PART OR PARTS OF THE ARCHITECTURAL OR ENGINEERING PROJECT.



Webster University
Interdisciplinary Science
Building

CANNONDESIGN

1100 Clark Avenue
St. Louis, Missouri 63102
T: 314.241.6250
F: 314.241.2570

William Tao & Associates, Inc.
MERFP Engineer
7955 Manchester Road, Suite 125
St. Louis, MO 63143
314-884-7600

David Mason & Associates, Inc.
Structural & Civil Engineer
800 South Vandeventer Avenue
St. Louis, MO 63110
314.534.1053

Faith Group
Technology
3101 S. Hanley Rd., Suite 100
St. Louis, MO 63143
314.591.2229

Kuhmann Leavitt, Inc.
Environmental Graphics & Signage
7400 Pershing Ave.
St. Louis, MO 63130
314.725.6616

KWA Architects
Architecture
3721 Litzinger Road
St. Louis, MO 63124
314.962.2560

Spellman Brady & Company
Interior Designer
8251 Maryland Avenue, Suite 300
St. Louis, MO 63105
314.862.0070

SWT Design
Landscape Architect
7722 Big Bend Blvd.
St. Louis, MO 63119
314.644.5700

Webb Engineering Services, Inc.
Plumbing & Fire Protection
1400 S. 3rd Street, Suite 201
St. Louis, MO 63104
314.588.0600

Panel: 1NL2													
Location: MAIN ELECTRICAL 192				Volts: 120/208 Wye				A.I.C. Rating: 10,000					
Supply From: SB-1				Phases: 3				Mains Type: MLO					
Mounting: S				Wires: 4				Mains Rating: 225 A					
Enclosure: Type 1								MCB Rating:					
CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	Main Electrical 192 - Receptacles	20 A	1	720	180					1	20 A	Teaching Kitchen 174 - Counter	2
3	Corridor C180 - Receptacles	20 A	1			540	4118			1	20 A	Teaching Kitchen 174 - Dish Washing	4
5	Bldg. Stor. 184, Cust. Stor. 186 - Receptacles	20 A	1					360	4118	1	20 A	Teaching Kitchen 174 - Island Apron	6
7	Toilet 180, 182 - Receptacles	20 A	1	360	0					1	20 A	Spare	8
9	Mechanical Room 178 - Receptacles	20 A	1			720	1800			1	20 A	Teaching Kitchen 174 - Microwave	10
11	Mechanical Room 178 - HHW-1	20 A	1					720	180	1	20 A	Teaching Kitchen 174 - Counter	12
13	Mechanical Room 178 - HHW-2	20 A	1	720	1500					1	20 A	Teaching Kitchen 174 - Refrigerator	14
15	Mechanical Room 178 - HHW-3	20 A	1			720	180			1	20 A	Teaching Kitchen 174 - Double Oven	16
17	Stair 2-1 - CUH-102	15 A	1					40	1000	1	20 A	Teaching Kitchen 174 - Refrigerator	18
19	Dock 172 - UH-101, Mech Rm 178 UH-102	15 A	1	48	2700					2	30 A	Teaching Kitchen 174 - Double Oven	20
21	Loading Dock 172, Recycling 172A ...	20 A	1			720	2700			1	20 A	Teaching Kitchen 174 - Counter	22
23	Elevator Control Room - Receptacle	20 A	1					180	180	1	20 A	Teaching Kitchen 174 - Island Apron	24
25	Elevator Control Room - VF-2	15 A	1	350	180					1	20 A	Teaching Kitchen 174 - Ansatl System	26
27	MDF Room - Receptacles	20 A	1			360	180			1	20 A	Teaching Kitchen 174 - Counter	28
29	MDF Room - Receptacles	20 A	1					360	180	1	20 A	Teaching Kitchen 174 - Island Apron	30
31	MDF Room - Receptacles	20 A	1	360	180					1	20 A	Teaching Kitchen 174 - Island Apron	32
33	MDF Room - Receptacles	20 A	1			360	180			1	20 A	Teaching Kitchen 174 - Island Computer	34
35	BLUE LIGHT EMERGENCY STATION	20 A	1					180	600	1	20 A	Teaching Kitchen 174 - Drop in Hood	36
37	Shunt Trip	20 A	1	360	0					1	20 A	Shunt Trip	38
39	Toilet 182 - Electric Hand Dryer	20 A	1			1490	1800			1	20 A	Teaching Kitchen 174 - Island Hood	40
41	Toilet 180 - Electric Hand Dryer	20 A	1					1490	0	--	--	Shunt Trip	42
43	Spare	20 A	1	0	360					1	20 A	Teaching Kitchen 174 - Projector/Monitor	44
45	Spare	20 A	1			0	360			1	20 A	Teaching Kitchen 174 - A/V Rack	46
47	Spare	20 A	1					0	540	1	20 A	Teaching Kitchen 174 - Wall Receptacles	48
49	Spare	20 A	1	0	0					1	20 A	Spare	50
51	Spare	20 A	1			0	0			1	20 A	Spare	52
53	Spare	20 A	1					0	0	1	20 A	Spare	54
Total Load:				8018 VA	16228 VA	10128 VA							
Total Amps:				67 A	138 A	87 A							
Notes:													

Panel: 1LL2													
Location: CORRIDOR C130				Volts: 120/208 Wye				A.I.C. Rating: 10,000					
Supply From: SB-2				Phases: 3				Mains Type: MCB					
Mounting: F				Wires: 4				Mains Rating: 225 A					
Enclosure: Type 1								MCB Rating:					
CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	Health Assessment Lab 131 - Teacher	20 A	1	720	360					1	20 A	Dry Skills Lab/Classroom 135 - Receptacles	2
3	Health Assessment Lab 131 - Receptacles	20 A	1			360	720			1	20 A	Dry Skills Lab/Classroom 135 - Monitors	4
5	Health Assessment Lab 131 - Monitor	20 A	1					360	0	1	20 A	Spare	6
7	Health Assessment Lab 131 - Desk	20 A	1	720	540					1	20 A	Dry Skills Lab/Classroom 135 - Surface...	8
9	Health Assessment Lab 131 - Desk	20 A	1			720	360			1	20 A	Dry Skills Lab/Classroom 135 - Surface...	10
11	Health Assessment Lab 131 - Desk	20 A	1					720	360	1	20 A	Dry Skills Lab/Classroom 135 - Surface...	12
13	Health Assessment Lab 131 - Desk	20 A	1	720	540					1	20 A	Dry Skills Lab/Classroom 135 - Desk	14
15	Health Assessment Lab 131 - Surface Raceway	20 A	1			360	540			1	20 A	Dry Skills Lab/Classroom 135 - Desk	16
17	Health Assessment Lab 131 - Surface Raceway	20 A	1					360	540	1	20 A	Dry Skills Lab/Classroom 135 - Desk	18
19	Health Assessment Lab 131 - A/V Receptacle	20 A	1	360	540					1	20 A	Dry Skills Lab/Classroom 135 - Desk	20
21	Sim Lab 133B - Receptacle	20 A	1			540	540			1	20 A	Dry Skills Lab/Classroom 135 - Desk	22
23	Sim Lab 133B - Receptacle	20 A	1					180	540	1	20 A	Dry Skills Lab/Classroom 135 - Desk	24
25	Sim Lab 133B - Receptacle	20 A	1	180	540					1	20 A	Dry Skills Lab/Classroom 135 - Desk	26
27	Sim Lab 133B - Receptacle	20 A	1			360	540			1	20 A	Dry Skills Lab/Classroom 135 - Desk	28
29	Sim Lab 133B - Receptacle	20 A	1					180	540	1	20 A	Models/Storage/Research 137 - Surface...	30
31	Control Room 133A - Monitor	20 A	1	180	540					1	20 A	Models/Storage/Research 137 - Surface...	32
33	Control Room 133A - Surface Raceway	20 A	1			360	540			1	20 A	Models/Storage/Research 137 - Surface...	34
35	Control Room 133A - Surface Raceway	20 A	1					360	180	1	20 A	Models/Storage/Research 137 - Surface...	36
37	Control Room 133A - Surface Raceway	20 A	1	180	180					1	20 A	Models/Storage/Research 137 - Receptacles	38
39	Control Room 133A - A/V Receptacle	20 A	1			360	180			1	20 A	Models/Storage/Research 137 - Receptacles	40
41	Control Room 133A - Surface Raceway	20 A	1					360	360	1	20 A	Dry Skills Lab/Classroom 135 - Movable Table	42
43	Control Room 133A - Surface Raceway	20 A	1	360	360					1	20 A	Dry Skills Lab/Classroom 135 - Floor Box	44
45	Control Room 133A - Surface Raceway	20 A	1			180	360			1	20 A	Dry Skills Lab/Classroom 135 - A/V Receptacle	46
47	Spare	20 A	1					0	360	1	20 A	Models/Storage/Research 137 - Receptacles	48
49	Spare	20 A	1	0	0					1	20 A	Spare	50
51	Spare	20 A	1			0	0			1	20 A	Spare	52
53	Spare	20 A	1					0	0	1	20 A	Spare	54
Total Load:				7020 VA	7020 VA	5400 VA							
Total Amps:				61 A	61 A	45 A							
Notes:													

Panel: 2LL1

Location: CORR-2 C280-2

Volts: 120/208 Wye

A.I.C. Rating: 10,000

Supply From: SB-2

Phases: 3

Mains Type: MCB/SFL

Mounting: S

Wires: 4

Mains Rating: 225 A

Enclosure: Type 1

MCB Rating:

CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT	
1	Cell Bio/Phys Research Lab 291 - Surface...	20 A	1	180	180			1	20 A Cell Bio/Phys Research Lab 291 - Desk	2	
3	Cell Bio/Phys Research Lab 291 - Surface...	20 A	1		180	180		1	20 A Cell Bio/Phys Research Lab 291 - Desk	4	
5	Cell Bio/Phys Research Lab 291 - Surface...	20 A	1			180	180	1	20 A Cell Bio/Phys Research Lab 291 - Desk	6	
7	Cell Bio/Phys Research Lab 291 - Surface...	20 A	1	180	180			1	20 A Cell Bio/Phys Research Lab 291 - Desk	8	
9	Cell Bio/Phys Research Lab 291 - Surface...	20 A	1		180	144		1	20 A Cell Bio/Phys Research Lab 291 - Desk	10	
11	Cell Bio/Phys Research Lab 291 - Surface...	20 A	1			360	180	1	20 A Tissue Culture B 289B - Surface Raceway	12	
13	Cell Bio/Phys Research Lab 291 - Surface...	20 A	1	360	180			1	20 A Tissue Culture B 289B - Surface Raceway	14	
15	Cell Bio/Phys Research Lab 291 - Surface...	20 A	1		180	180		1	20 A Tissue Culture B 289B - Receptacle	16	
17	Cell Bio/Phys Research Lab 291 - Fume Hood	20 A	1			500	180	1	20 A Tissue Culture B 289B - Receptacle	18	
19	Cell Bio/Phys Research Lab 291 - Surface...	20 A	1	360	492			1	20 A Tissue Culture B 289B - Refrigerator	20	
21	Cell Bio/Phys Research Lab 291 - UC Glass...	20 A	1		180	0		1	20 A Spare	22	
23	Cell Bio/Phys Research Lab 291 - Teacher	20 A	1			720	0	1	20 A Spare	24	
25	Cell Bio/Phys Research Lab 291 - Projector	20 A	1	500	0			1	20 A Spare	26	
27	Cell Bio/Phys Research Lab 291 - A/V Cabinet	20 A	1		360	0		1	20 A Spare	28	
29	Cell Bio/Phys Research Lab 291 - Shades	20 A	1			540	0	1	20 A Spare	30	
31	Cell Bio/Phys Research Lab 291 - BSC	20 A	1	1130	0			1	20 A Spare	32	
33	Cell Bio/Phys Research Lab 291 - Desk	20 A	1		180	0		1	20 A Spare	34	
35	Cell Bio/Phys Research Lab 291 - Desk	20 A	1			180	0	1	20 A Spare	36	
37	Spare	20 A	1	0	0			1	20 A Spare	38	
39	Spare	20 A	1		0	0		1	20 A Spare	40	
41	Spare	20 A	1			0	0	1	20 A Spare	42	
Total Load:				3742 VA	1764 VA	3020 VA					
Total Amps:				33 A	15 A	27 A					

Notes:

Panel: 1NL1												
Location: ELEC 110B				Volts: 120/208 Wye				A.I.C. Rating: 10,000				
Supply From: SB-1				Phases: 3				Mains Type: MCB/SFL				
Mounting: S				Wires: 4				Mains Rating: 225 A				
Enclosure: Type 1								MCB Rating:				
CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT		
1	Power Elec 11.0B.1	20 A	1	900 VA 360 VA			1	20 A	Office NUNNA ADJ 144 - Receptacles	2		
3	Power Mock Beds Stor	7.10	20 A	1	540 VA 360 VA		1	20 A	Office NUNNA ADJ 144 - Receptacles	4		
5	Power Nursing 7.03.3	20 A	1			540 VA 360 VA	1	20 A	Office NUNNA ADJ 144 - Receptacles	5		
7	Power Anesthesia 6.08.3	20 A	1	540 VA 180 VA			1	20 A	Work/Copy 100A - Counter	8		
9	Power Corridor 102 USB	20 A	1		180 VA 180 VA		2	30 A	Work/Copy 100A - Printer	10		
11	Power Staff (2) 9.06.1	20 A	1			720 VA 180 VA	1	20 A	Kettle 100C - Counter	12		
13	Power Anesthesia 6.08.2	20 A	1	720 VA 360 VA			1	30 A	Kettle 100C - Counter	14		
15	Power Nursing 7.03.2	20 A	1		720 VA 1656		1	30 A	Kettle 100C - GDI-1	16		
17	Power Nursing 7.03.4	20 A	1			720 VA 1000	1	20 A	Kettle 100C - Refrigerator	18		
19	Power Nursing 7.03.6	20 A	1	180 VA 360 VA			1	20 A	Kettle 100C - Desk	20		
21	Power Mock Beds 7.10	20 A	1		720 VA 360 VA		1	20 A	Kettle 100C - Desk	22		
23	Power Conf Rm 24 Seats 10.06 Monitor	20 A	1			360 VA 540 VA	1	20 A	Elev 1 Pkt, JC 175, Corridor C180	24		
25	Power Conference Room 24 Seats 10.06	20 A	1	360 VA 370 VA			1	20 A	EWC-1	26		
27	Power Conference Room 24 Seats 10.06	20 A	1		540 VA 360 VA		1	20 A	Women 177, Men 179	28		
29	Power Conference Room 24 Seats 10.06	20 A	1			540 VA 180 VA	1	20 A	Data - 100B	30		
31	Power Conference Room 24 Seats 10.06	20 A	1	360 VA 180 VA			1	20 A	Corridor C140 - Digital Signage	32		
33	Power Commons 2.10.04-2	20 A	1		540 VA 180 VA		1	20 A	Elev 1 - ESP-1	34		
35	Power Vending 11.28	20 A	1			180 VA 720 VA	1	20 A	Power Rm 114,116	36		
37	Power Vending 11.28	20 A	1	180 VA 180 VA			1	20 A	Power Rm 154	38		
39	Power Vending 11.28	20 A	1		180 VA 720 VA		1	20 A	Power Conference Room 24 Seats, Shade	40		
41	Power Vending 11.28	20 A	1			180 VA 1490	1	20 A	Men 179 - Electric Hand Dryer	42		
43	Power Conf Rm 154	20 A	1	1260	1490		1	20 A	Women 177 - Electric Hand Dryer	44		
45	Power Conf Rm 154 Monitor	20 A	1		180 VA 0 VA		1	20 A	Spare	46		
47	Power Sin May Green Rm 75.56 Monitor	20 A	1			180 VA 0 VA	1	20 A	Spare	48		
49	Vest, C153 - Elec Door Opener	20 A	1	360 VA 0 VA			1	20 A	Spare	50		
51	Vest, C153 - CUH-101	15 A	1		40 VA 0 VA		1	20 A	Spare	52		
53	Fire Protection Rm 137A - 100A	20 A	1			528 VA 360 VA	1	20 A	Ext of Receptacles	54		
55	Spare	20 A	1	0 VA 0 VA			1	20 A	Spare	56		
57	Spare	20 A	1		0 VA 0 VA		1	20 A	Spare	58		
59	Spare	20 A	1			0 VA 0 VA	1	20 A	Spare	60		
Total Load:				8340 VA	7456 VA	8778 VA						
Total Amps:				71 A	62 A	74 A						