

© Cannon Design 2015
All rights reserved. No part of this document may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying and recording, or by any information storage or retrieval system, without written authorization by The Cannon Corporation.
5/24/2016 8:36:03 AM

LIGHTING FIXTURE SCHEDULE 3 OF 3												
TYPE (I)	GENERAL DESCRIPTION, ACCESSORIES, AND APPLICATION	LIGHT SOURCE DATA				DRIVER/BALLAST		FIXTURE VOLTAGE	INPUT POWER	MANUFACTURER AND CATALOG NUMBER SERIES (V)	NOTES (VI)	
		TYPE (II)	QTY X WATTS/ LAMP	LAMP CODE / LED MODULE	LED DELIVERED LUMENS	LED L70 RATED LIFE	CONTROL TYPE (III)					DIMMING ENABLED TO
RD	RECESSED 4" DIAMETER ROUND, SELF-FLANGED, 3,000K LED FIXED DOWNLIGHT, WITH INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	1,300	50,000	0-10V DIM	10%	277	22 W	PORTFOLIO LD4A-13-D010TE-ERM4A13-30-4LM1-H PRESCOLITE, AMERLUX	3
RE	RECESSED 4" SQUARE, SELF-FLANGED, 3,000K LED ADJUSTABLE DOWNLIGHT, WITH INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	1,075	50,000	0-10V DIM	10%	277	16 W	USA13131-B1-S-10-AL30F-LSTA4-8416-C3-30KH-25-NC-277-DIML2 PRESCOLITE, AMERLUX	
RED	RECESSED 4" SQUARE, MUD-IN TRIM, 3,000K LED DOWNLIGHT, WITH INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	1,075	50,000	0-10V DIM	1%	277	16 W	USA1 1011-B1-10-LSLD4-8020-M2-30KS-50-NCSCM-277-DIML6A PRESCOLITE, AMERLUX	3
RF	RECESSED 8" LONG X 5" WIDE X 5" HIGH, 3,000K LED LENSED WALLWASHER WITH INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	877	50,000	0-10V DIM	10%	277	17 W	ELLIPTIPAR S-222-M007-L-02-M-0-30-2X	3
RG	RECESSED 2" WIDE X 2" LONG, X 5" DEEP, 3,500K LED TROFFER, WITH STAINLESS STEEL DOORFRAME, DOORFRAME GASKET, GRID CEILING, DIFFUSING FILM, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	6,747	80,000	0-10V DIM	10%	277	74 W	KENALL CSEDO-22-67L35K-277-5F-2H KURTZON, NEW STAR	18
RH	RECESSED 4" DIAMETER ROUND, SELF-FLANGED, 3,000K LED FIXED DOWNLIGHT, WITH WIDE DISTRIBUTION AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	1,800	50,000	0-10V DIM	10%	277	32 W	PORTFOLIO LD4A-18-D010TE-ERW4A18-30-4LW1-H PRESCOLITE, AMERLUX	3
RHB	RECESSED 4" DIAMETER ROUND, SELF-FLANGED, 3,000K LED FIXED DOWNLIGHT, SUITABLE FOR 2.75" THICK BASWAPHON CEILING, WITH WIDE DISTRIBUTION AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	1,800	50,000	0-10V DIM	10%	277	32 W	PORTFOLIO LD4A-18-D010TE-ERW4A18-30-4LW1-H- 2.75" CEILING PRESCOLITE, AMERLUX	3
RJ4	SEMI-RECESSED COMBOLIGHT, WITH FOUR 3,000K ADJUSTABLE LED SPOT LIGHTS WITH FLOOD DISTRIBUTION, 45X360 DEGREE ADJUSTABILITY, MUD-IN FLANGE, AND INTEGRAL 1% DIMMING DRIVERS, CONFIGURED FOR TWO CIRCUIT CONTROL.	LED	NA	FURNISHED WITH FIXTURE	4,800	50,000	0-10V DIM	1%	277	64 W	AMERLUX HORNET-HP-SRTLX-FRAME-4-LED-277-0-10V/HORNET-HP-SRTLX-FRAME-4-16-LED-WT-120-277-FL-F-L-FL-FL-3000-0-10V-2-CKT MOD) CONTECH RDA4L	1,3
RK2	RECESSED 2" WIDE X 2" LONG X 5" DEEP, 3,500K LED TROFFER, WITH REGRESSED ALUMINUM DOORFRAME, GRID CEILING, SATIN WHITE LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	3,300	70,000+	0-10V DIM	10%	277	36 W	LITHONIA 2GTL-2-20L-RW-SWL-EZ1-LP835 SPOOPER, COLUMBIA	
RL	RECESSED 4" DIAMETER ROUND, SELF-FLANGED, 3,000K LED ADJUSTABLE DOWNLIGHT, WITH INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	1,300	50,000	0-10V DIM	10%	277	23 W	PORTFOLIO LD4A-13-D010TE-LAR35FL-4LA1-W-WF AMERLUX, PRESCOLITE	3
RM2	RECESSED 2" WIDE X 2" LONG X 4" DEEP, 3,000K LED ARCHITECTURAL TROFFER, GRID CEILING, SATIN WHITE LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	3,000	50,000	0-10V DIM	5%	277	29 W	AXIS DIALED-22-B3-3000-80-30-VL-W-277-D-1-GRID PINNACLE, JUNO, LUMENWERX	
RM4	RECESSED 2" WIDE X 4" LONG X 4" DEEP, 3,000K LED ARCHITECTURAL TROFFER, GRID CEILING, SATIN WHITE LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	4,500	50,000	0-10V DIM	5%	277	38 W	AXIS DIALED-24-B3-4500-80-30-VL-W-277-D-1-GRID PINNACLE, JUNO, LUMENWERX	
RN	RECESSED 4" WIDE X 5" DEEP X 4" LONG, 3,000K LED DIRECT LUMINAIRE, HIGH OUTPUT, WOOD CEILING, FLUSH DIFFUSING LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	2,500	50,000+	0-10V DIM	10%	277	37 W	FINELITE HP-4R-LENGTH-30-3000K-277V-SC-WOOD-DIM AXIS, PRUDENTIAL, MARK, PINNACLE	3
RP16	RECESSED 4" WIDE X 5" DEEP X 16" LONG, 3,000K LED DIRECT LUMINAIRE, GRID CEILING, REGRESSED DIFFUSING LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	12,000	50,000+	0-10V DIM	10%	277	112 W	AXIS BBRLED-B3-MF-750-80-30-RG-LENGTH-W-277-D-1-GRID FOCALPOINT, PINNACLE, MARK, PRUDENTIAL	
RP20	RECESSED 4" WIDE X 5" DEEP X 20" LONG, 3,000K LED DIRECT LUMINAIRE, GRID CEILING, REGRESSED DIFFUSING LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	15,000	50,000+	0-10V DIM	10%	277	140 W	AXIS BBRLED-B3-MF-750-80-30-RG-LENGTH-W-277-D-1-GRID FOCALPOINT, PINNACLE, MARK, PRUDENTIAL	
RP24	RECESSED 4" WIDE X 5" DEEP X 24" LONG, 3,000K LED DIRECT LUMINAIRE, GRID CEILING, REGRESSED DIFFUSING LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	18,000	50,000+	0-10V DIM	10%	277	168 W	AXIS BBRLED-B3-MF-750-80-30-RG-LENGTH-W-277-D-1-GRID FOCALPOINT, PINNACLE, MARK, PRUDENTIAL	
RP28	RECESSED 4" WIDE X 5" DEEP X 28" LONG, 3,000K LED DIRECT LUMINAIRE, GRID CEILING, REGRESSED DIFFUSING LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	21,000	50,000+	0-10V DIM	10%	277	196 W	AXIS BBRLED-B3-MF-750-80-30-RG-LENGTH-W-277-D-1-GRID FOCALPOINT, PINNACLE, MARK, PRUDENTIAL	
RQ	RECESSED 8" WIDE PERIMETER TROFFER SYSTEM, WITH SINGLE LAMP SPACING, SHADOWLINE ANGLE, AND INTEGRAL EMERGENCY BALLAST (WHERE SHADED ON PLANS), FIXTURE TO MATCH EXISTING EAB FIXTURES.	F	1X28	PHILIPS F28T5/835	NA	NA	NA	NA	277	33 W	LINEAR LIGHTING WW4-D1ET5-XX-SN-R-XX NO EQUAL	14
RR4X4	RECESSED LINEAR 4" APERTURE, 4'X4' GRID MOUNTED, STANDARD OUTPUT, 3,000K LED	LED	NA	FURNISHED WITH FIXTURE	4,836	100,000+	0-10V DIM	10%	277	66 W	FINELITE HP-4R-14'-8"-SO-3000K-277V-SC-GRID-DIM AXIS, PRUDENTIAL, PINNACLE, MARK	11,16
RR4X6	RECESSED LINEAR 4" APERTURE, 4'X6' GRID MOUNTED, STANDARD OUTPUT, 3,000K LED	LED	NA	FURNISHED WITH FIXTURE	6,155	100,000+	0-10V DIM	10%	277	83 W	FINELITE HP-4R-18'-8"-SO-3000K-277V-SC-GRID-DIM AXIS, PRUDENTIAL, PINNACLE, MARK	11,16
RR6X8	RECESSED LINEAR 4" APERTURE, 6'X8' GRID MOUNTED, STANDARD OUTPUT, 3,000K LED	LED	NA	FURNISHED WITH FIXTURE	8,793	100,000+	0-10V DIM	10%	277	208 W	FINELITE HP-R4-26'-8"-SO-3000K-277V-SC-GRID-DIM AXIS, PRUDENTIAL, PINNACLE, MARK	11,16
RS8	RECESSED 4" WIDE X 5" DEEP X 8" LONG, 3,000K LED DIRECT LUMINAIRE, HIGH OUTPUT, GRID CEILING, FLUSH DIFFUSING LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	5,100	50,000	0-10V DIM	.1%	277	74 W	FINELITE HP-4R-8'-HO-3000K-277V-SC-GRID-DIM-.1% AXIS, PINNACLE, MARK	
SA	3,000K LED TAPELIGHT MOUNTED WITHIN A 3/4" WIDE X 1" TALL ALUMINUM CHANNEL, WITH DIFFUSING LENS AND REMOTE CLASS II DIMMING DRIVERS.	LED	NA	FURNISHED WITH FIXTURE	750 LM/FT	40,000+	0-10V DIM	10%	277	80 W	LEDLINEAR HYDRA-LD25-W830/LENGTH-DL-003-ROUND COVER-IP40-ADJ-FEET-0/10V	1,7,13
UA2	NOMINAL 2' LONG, EXTRUDED ALUMINUM, 3,000K LED UNDERCABINET LIGHT WITH 100% DR IMPACT RESISTANT ACRYLIC, INTEGRAL SWITCH, AND INTEGRAL DRIVER.	LED	NA	FURNISHED WITH FIXTURE	700	120,000+	SWITCHED	NA	277	11 W	KENALL AUCLCD-I-FINISH-11L30K-24"-120V-MS-SW	1
UA4	NOMINAL 4' LONG, EXTRUDED ALUMINUM, 3,000K LED UNDERCABINET LIGHT WITH 100% DR IMPACT RESISTANT ACRYLIC, INTEGRAL SWITCH, AND INTEGRAL DRIVER.	LED	NA	FURNISHED WITH FIXTURE	1,287	120,000+	SWITCHED	NA	277	20 W	KENALL AUCLCD-I-FINISH-20L30K-48"-120V-MS-SW	1
UB4	NOMINAL 4' LONG, EXTRUDED ALUMINUM, 3,000K LED UNDERCABINET LIGHT WITH INTEGRAL SWITCH, MAGNETIC MOUNTING CLIPS, REMOTE DRIVER, AND CORD AND PLUG CONNECTION.	LED	NA	FURNISHED WITH FIXTURE	760	50,000	SWITCHED	NA	120	12 W	FINELITE UC-E-45'-FINISH-PS-21W-MAGNETICMOUNT	1,4
WA	RECESSED 4" WIDE X 5" DEEP X 4" LONG, WALL MOUNTED, 3,000K LED DIRECT LUMINAIRE, STANDARD OUTPUT, FLUSH DIFFUSING LENS, AND INTEGRAL DIMMING DRIVER.	LED	NA	FURNISHED WITH FIXTURE	1,348	168,000	0-10V DIM	10%	277	18 W	FINELITE HP-4R-SO-3000K-277V-SC-SF	1,3
XA	UNIVERSAL MOUNTED, SINGLE OR DOUBLE FACED, AC POWERED, THERMOPLASTIC EXIT SIGN WITH WHITE HOUSING AND RED LETTERING.	LED	NA	FURNISHED WITH FIXTURE	NA	NA	NA	NA	277	4 W	LITHONIA LQM-S-W-3-R-120/277 SURELITES, DUAL-LITE	1
XB	WALL/BACK MOUNTED, EDGE-LIT, AC POWERED, SINGLE FACED, LED EXIT SIGN WITH EXTRUDED ALUMINUM BODY AND RED LETTERING.	LED	NA	FURNISHED WITH FIXTURE	NA	NA	NA	NA	277	4 W	LITHONIA LRP-1-RC-120/277 SURELITES, DUAL-LITE	1
XC	CEILING MOUNTED, EDGE-LIT, AC POWERED, SINGLE OR DOUBLE FACED, LED EXIT SIGN WITH EXTRUDED ALUMINUM BODY AND RED LETTERING. REFER TO PLANS FOR SINGLE OR DOUBLE FACED CONFIGURATION.	LED	NA	FURNISHED WITH FIXTURE	NA	NA	NA	NA	277	4 W	LITHONIA LRP-FACES-LETTERS/BACKGROUND-120/277 SURELITES, DUAL-LITE	1
YA	SURFACE MOUNTED, "IN USE" CUSTOM SIGNAGE LIGHT WITH INTEGRAL DRIVER.	LED	NA	FURNISHED WITH FIXTURE	NA	NA	SWITCHED	NA	277	18 W	DUALITE LE-W-S-G-FINISH-AC-SW3 ISOLITE	
ZB	OWNER FURNISHED, CONTRACTOR INSTALLED OR LIGHT.								120	500 W		17

DESIGNATION METHOD (I)

FIRST CHARACTER DESIGNATES MOUNTING OR TYPE.

SECOND CHARACTER IS SEQUENTIAL LETTERING TO IDENTIFY DIFFERENT FIXTURE SERIES FOR SIMILAR MOUNTING TYPES.

NUMBERED SUFFIX DIFFERENTIATES SPECIAL VARIATIONS OF SIMILAR FIXTURES USED IN THE PROJECT.

MOUNTING OR TYPE

B = WALL BRACKET OR WALL SURFACE

C = COVE OR NICHE MOUNTED

E = EXTERIOR

P = PENDANT

R = RECESSED IN CEILING

S = SURFACE CEILING MOUNTED

W = WALL RECESSED

X = EXIT

Y = BATTERY

Z = SPECIAL

LAMP CODE (II)

C = FLUORESCENT/STRAIGHT

I = INCANDESCENT

M = METAL HALIDE

P = COMPACT FLUORESCENT

LED = LIGHT EMITTING DIODE

CONTROL TYPE (III)

ON/OFF = SINGLELEVEL, ON/OFF CONTROL

2 CKT = TWO ELECTRICAL FEEDS SERVING LUMINAIRE

STEP DIM = 100% OUTPUT, REDUCED OUTPUT, AND OFF

0 - 10V = 0-10 VOLT DIMMING CONTROL

DIM = DIGITALLY ADDRESSABLE LIGHTING INTERFACE

DUAL DIM = DIGITALLY ADDRESSABLE DIMMING (LUTRON)

ECO DIM = 2-WIRE, POWERLINE, FORWARD PHASE

INC DIM = DIMMING

ELV DIM = 2-WIRE, POWERLINE, REVERSE PHASE DIMMING

SW DIM = 3-WIRE, HOT + NEUTRAL + DIMMED HOT

OTHER = REFER TO GENERAL DESCRIPTION FOR DETAILS

WATTS PER FIXTURE (IV)

TOTAL INPUT WATTS PER FIXTURE

INCLUDING

ALL LAMPS AND BALLASTS

MANUFACTURER AND CATALOG NUMBER SERIES (V)

A THE LISTED MANUFACTURER NUMBERS MAY NOT BE COMPLETE. THE CONTRACTOR IS RESPONSIBLE FOR FURNISHING FIXTURES WHICH COMPLY WITH THE MANUFACTURER NUMBER INDICATED AS WELL AS ALL OTHER CRITERIA NOTED IN THE FIXTURE SCHEDULE, THE FIXTURE SCHEDULE NOTES AND DIVISION 28 SPECIFICATIONS. THE CONTRACTOR/MANUFACTURER SHALL CONTACT ENGINEER PRIOR TO BID, REGARDING ANY CONFLICTS BETWEEN THE CATALOG NUMBER, FIXTURE SCHEDULE OR SPECIFICATION. ANY MEASURES REQUIRED TO RECTIFY SCHEDULE CONFLICTS NOT IDENTIFIED BY THE CONTRACTOR PRIOR TO BIDDING, SHALL BE PROVIDED BY THE CONTRACTOR AT NO ADDITIONAL COST.

B THE FIRST-NAMED MANUFACTURER AND CATALOG NUMBER LISTED FOR EACH FIXTURE TYPE IDENTIFIES THE STANDARDS OF PERFORMANCE, FABRICATION AND AESTHETICS REQUIRED. PRODUCTS OF EQUAL OR SUPERIOR PERFORMANCE, FABRICATION AND AESTHETICS BY SECOND AND THIRD-NAMED MANUFACTURERS SHALL BE CONSIDERED EQUAL AND MAY BE SUBMITTED FOR REVIEW IN ACCORDANCE WITH THE REQUIREMENTS FOR SHOP DRAWING SUBMITTALS DETAILED IN SPECIFICATION SECTION 285100.

C IT IS THE CONTRACTOR'S RESPONSIBILITY TO PROVIDE THE APPROPRIATE MODEL AND SERIES OF THE PRODUCT TO BE SUBMITTED BY SECOND AND THIRD-NAMED MANUFACTURERS LISTED. THE ENGINEER RESERVES THE RIGHT TO REJECT ANY PRODUCT WHICH DOES NOT MEET OR EXCEED THE ATTRIBUTES OF THE FIRST-NAMED MANUFACTURER.

D THE PRODUCTS OF ANY MANUFACTURER NOT LISTED ON THE FIXTURE SCHEDULE SHALL BE CONSIDERED A SUBSTITUTION. ANY SUBSTITUTIONS MUST BE SUBMITTED TO THE ENGINEER BY THE CONTRACTOR FOR REVIEW PRIOR TO BID SUBMITTALS IN ACCORDANCE WITH SPECIFICATION SECTION 285100. THE ENGINEER RESERVES THE RIGHT TO REJECT ANY SUBSTITUTION SUBMITTAL AFTER AWARD OF CONTRACT REQUESTS FOR SUBSTITUTION WILL BE REJECTED UNLESS DIRECTED AND APPROVED BY OWNER AS ADDITIONAL SERVICE.

E WHERE ONLY ONE MANUFACTURER IS LISTED AND "NO EQUAL" IS CALLED OUT IN THE SCHEDULE, THE ENGINEER WILL REJECT ANY ALTERNATIVE FIXTURES SUBMITTED. THE ANTICIPATED DISTRIBUTOR COST FOR THE SPECIFIED FIXTURE WILL BE ON FILE WITH THE ENGINEER.

F TO ENSURE THE SHOP DRAWING PREPARER HAS ALL NECESSARY INFORMATION, CONTRACTOR SHALL SUBMIT SHOP DRAWING IN ACCORDANCE WITH SPECIFICATIONS INCLUDING THE FOLLOWING: ONE FULL SIZE COPY OF THE LIGHTING FIXTURE SCHEDULE SIGNED BY THE DISTRIBUTOR OR FIXTURE REPRESENTATIVE WHO PREPARED THE SUBMITTAL.

G LAMP AND BALLAST/DRIVER MANUFACTURER CUT SHEETS SHALL BE INCLUDED WITH SHOP DRAWING SUBMITTAL FOR EACH FIXTURE TYPE.

H WHILE MANUFACTURER GENERIC DRIVER DESIGNATIONS ARE USED, CONTRACTOR SHALL PROVIDE DRIVER MAKES AND MODELS WHICH COMPLY WITH THE DIMMING REQUIREMENTS IDENTIFIED ON THE LIGHT FIXTURE SCHEDULE.

LIGHTING FIXTURE SCHEDULE NOTES (VI)

GENERAL NOTES

- CONTRACTOR AND FIXTURE MANUFACTURER SHALL BE RESPONSIBLE FOR COMPLYING WITH DIVISION 28 SEISMIC REQUIREMENTS AND SPECIFICATION SECTION 28240 - VIBRATIONS AND SEISMIC CONTROLS.
- ALL FIXTURES SHALL BE PAINTED AFTER FABRICATION.
- SEE PLANS FOR MOUNTING HEIGHTS AND SUSPENSION HEIGHTS NOT LISTED HERE.
- ALL RECESSED AND SURFACE-MOUNTED TROFFERS SHALL HAVE SPRING-LOADED CAM LATCHES AND T-HINGES ON DOOR FRAMES.
- ALL PRISMATIC TROFFERS SHALL BE PROVIDED WITH REGRESSED WHITE, ALUMINUM DOOR FRAME.
- ALL "E" DESIGNATION EXTERIOR FIXTURE SHALL BE UL LISTED FOR WET LOCATIONS (OR DAMP LOCATION UNDER EXTERIOR SOFFITS).
- CONTRACTOR SHALL BE RESPONSIBLE FOR FURNISHING AND INSTALLING THE CORRECT EXIT SIGN FIXTURE ORIENTATION, APPROPRIATE MOUNTING BRACKETS, ILLUMINATED FACES, AND DIRECTIONAL CHEVRONS AS INDICATED ON PLANS.
- ALL FLUORESCENTS BALLASTS AND LED DRIVERS SHALL BE INTEGRAL TO FIXTURE UNLESS OTHERWISE NOTED.
- CONTRACTOR SHALL NOT USE ELECTRICAL DRAWINGS FOR EXACT LIGHT FIXTURE ROUGH-IN LOCATIONS. REFER TO ARCHITECTURAL PLANS.

KEYED NOTES

- COORDINATE STANDARD COLOR FINISH WITH ARCHITECT.
- COORDINATE CUSTOM COLOR FINISH WITH ARCHITECT.
- DRIVER SHALL BE ACCESSIBLE AND REMOVABLE THROUGH CEILING OPENING.
- PROVIDE REMOTE BALLAST(S)/DRIVER(S) LOCATED IN AN ACCESSIBLE LOCATION.
- PENDANT LENGTHS VARY. BOTTOM OF FIXTURE TO BE A 8'-0" AFF.
- REFER TO ARCHITECTURAL PLANS FOR COVE LENGTHS. FIXTURE LENGTHS INDICATED ARE APPROXIMATE. PROVIDE FIXTURE QUANTITIES AND LENGTHS AS REQUIRED FOR FIXTURES TO RUN CONTINUOUS ALONG ENTIRE LENGTH OF COVE.
- CONTRACTOR SHALL PROVIDE ALL MISCELLANEOUS LOW VOLTAGE AND LINE VOLTAGE LIGHTING, ACCESSORIES, AND HARDWARE TO SUPPORT, POWER, AND CONTROL FIXTURE AS PER SPECIFIC INSTALLATION AND AS RECOMMENDED BY THE MANUFACTURER. SEE PLANS FOR LENGTHS, LAYOUTS AND CIRCUITING.
- REFER TO ELECTRICAL PLANS, ARCHITECTURAL PLANS AND SECTIONS FOR MOUNTING INFORMATION.
- FINISH/COLOR CHIPS SHALL BE FURNISHED WITH SHOP DRAWINGS FOR SELECTION AND APPROVAL BY OWNER/ARCHITECT/ENGINEER.
- PROVIDE FIXTURE EQUIPPED WITH HONEYCOMB LOUVER AND SNOOT.
- MANUFACTURER SHALL SUPPLY TWO SETS OF CUSTOM SHOP DRAWINGS. FIRST, CONCEPT DRAWINGS WILL BE SUBMITTED FOR APPROVAL BY ARCHITECT/ENGINEER. SECOND, ONE DETAILED SET OF SHOP DRAWINGS SHALL BE SUBMITTED FOR FINAL REVIEW. DETAILED SHOP DRAWINGS SHALL INCLUDE PROJECT SPECIFIC SCHEMATIC DRAWINGS.
- SUBMIT POINT BY POINT CALCULATION SHOWING MAINTAINED LIGHT LEVELS ON THE GROUND FOR ALL PAVED SURFACES. POINTS SHALL BE SPACED A MAXIMUM OF 10' O.C. LIGHT LEVELS SHALL NOT FALL BELOW .25 FC.
- PROVIDE FIXTURE LENGTHS AND QUANTITIES AS REQUIRED FOR A CONTINUOUS INSTALLATION FROM WALL TO WALL. LOCATE START/END OF FIXTURES WITHIN 6" OF WALL.
- COORDINATE INSTALLATION OF NEW FIXTURES WITH MANUFACTURER AND EXISTING FIXTURES, TO ACHIEVE A SEAMLESS CONTINUATION OF THE EXISTING COVE.
- REFER TO PLANS FOR FIXTURE LENGTHS AND CONFIGURATIONS.
- REFER TO ARCHITECTURAL PLANS AND DETAILS FOR FIXTURE CONFIGURATIONS.
- COORDINATE ALL MOUNTING AND POWER REQUIREMENTS WITH OWNER.
- PROVIDE "RF" RADIO FREQUENCY FILTER TO FIXTURES IN SIMULATION LAB.

THE SEALS(S) AND SIGNATURE(S) APPLY ONLY TO THE DOCUMENT TO WHICH THEY ARE AFFIXED, AND EXPRESSLY DISCLAIM ANY RESPONSIBILITY FOR ALL OTHER PLANS, SPECIFICATIONS, ESTIMATES, REPORTS OR OTHER DOCUMENTS OR INSTRUMENTS RELATING TO OR INTENDED TO BE USED FOR ANY PART OR PARTS OF THE ARCHITECTURAL OR ENGINEERING PROJECT.



Webster University
Interdisciplinary Science
Building

CANNONDESIGN

1100 Clark Avenue
St. Louis, Missouri 63102
T: 314.241.6250
F: 314.241.2570

William Tao & Associates, Inc.
ME/PFP Engineer
7955 Manchester Road, Suite 125
St. Louis, MO 63143
314-884-7600

David Mason & Associates, Inc.
Structural & Civil Engineer
800 South Vandeventer Avenue
St. Louis, MO 63110
314-534-1053

Faith Group
Technology
3101 S. Hanley Rd., Suite 100
St. Louis, MO 63143
314-591-2238

Kuhlmann Leavitt, Inc.
Environmental Graphics & Signage
7400 Pershing Ave.
St. Louis, MO 63130
314.725.6616

KWA Architects
Architecture
8721 Litzinger Road
St. Louis, MO 63124
314.962.2560

Spellman Brady & Company
Interior Designer
8251 Maryland Avenue, Suite 300
St. Louis, MO 63105
314-862-0070

SWT Design
Landscape Architect
7722 Big Bend Blvd
St. Louis, MO 63119
314.644.5700

Webb Engineering Services, Inc.
Planning & Fire Protection
1400 S. 3rd Street, Suite 201
St. Louis, MO 63104
314.588.0600

CONFORMED SET 01 JUL 2016

3	ADDENDUM 2-4	24 MAY 2016
2	ADDENDUM 2-2	19 APRIL 2016
1	ADDENDUM 2-1	17 MAR 2016
-	ISSUED FOR CONSTRUCTION (BP2)	01 MAR 2016

No.	Description	Date
Drawing Title:		
LIGHT FIXTURE SCHEDULE		
Project No.: 04561.01		
Checked by:		

E0702