

© Cannon Design 2015
All rights reserved. No part of this document may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, recording, or by any information storage and retrieval system, without written authorization by The Cannon Corporation.
4/19/2016 10:01:01 AM

EQUIPMENT DATA SCHEDULE															
	MARK		KW HP MCA	VOLTAGE PHASE SPEED	EQUIPMENT LOCATION	CONTROLLER DATA			PANEL DESIGNATION	BRANCH CIRCUIT DATA			GROUND	CONDUIT SIZE	NOTES
	ID	TAG #				ACCESORIES (1)	CONTROLLER TYPE (2)	CONTROLLER SIZE		TYPE (3)	SIZE	PHASE			
CENTRAL AIR COMPRESSOR	AC	1	(3) 7.5 HP	480/3/1	LEVEL 01 AREA A		PWCP	-	1NH2	CB	70A/3P	6	10	3/4"	
AIR COOLED CONDENSING UNIT	ACCU	1	16 MCA	208/1/1	LEVEL 0 MECH RM	-	PWCP	-	BNL1	CB	25A/2P	10	10	3/4"	4
AIR COOLED CONDENSING UNIT	ACCU	2	16 MCA	208/1/1	LEVEL 0 MECH RM	-	PWCP	-	BNL1	CB	25A/2P	10	10	3/4"	4
AIR COOLED CONDENSING UNIT	ACCU	3	16 MCA	208/1/1	ROOF	-	PWCP	-	4NL1	CB	25A/2P	10	10	3/4"	4
AIR COOLED CONDENSING UNIT	ACCU	4	16 MCA	208/1/1	ROOF	-	PWCP	-	4NL1	CB	25A/2P	10	10	3/4"	4
AIR COOLED CONDENSING UNIT	ACCU	5	26 MCA	208/1/1	LEVEL 0 MECH RM	-	PWCP	-	BNL1	CB	40A/2P	8	10	3/4"	4
AIR HANDLING UNIT	AHU	1	100 MCA	480/3/VAR	LEVEL 0 MECH RM	-	VFD	-	BNH1	CB	180A/3P	3/0	6	2"	3, 6, 7
AIR HANDLING UNIT	AHU	2	100 MCA	480/3/VAR	LEVEL 0 MECH RM	-	VFD	-	BNH1	CB	180A/3P	3/0	6	2"	3, 6, 7
AIR HANDLING UNIT	AHU	3	6 MCA	480/3/VAR	LEVEL 0 MECH RM	-	VFD	-	1SH1	CB	15A/3P	12	12	3/4"	2, 6
AIR HANDLING UNIT	AHU	4	6 MCA	480/3/VAR	LOWER LEVEL	-	VFD	-	1SH1	CB	15A/3P	12	12	3/4"	2, 6
AIR HANDLING UNIT	AHU	5	10.47 MCA	480/3/VAR	LEVEL 01 - ELECTRICAL RM	-	VFD		1NH2	CB	15A/3P	12	12	3/4"	6
BOILER	B	1	10.2 MCA	120/1/1	LEVEL 01 AREA A	-	PWCP	-	1SL1	CB	20A/1P	12	12	3/4"	2, 4
BOILER	B	2	10.2 MCA	120/1/1	LEVEL 01 AREA A	-	PWCP	-	1SL1	CB	20A/1P	12	12	3/4"	2, 4
CHILLED WATER PUMP	CP	1	25 HP	480/3/VAR	LEVEL 0 MECH RM	-	VFD	-	BNH1	CB	70A/3P	6	10	3/4"	6
CHILLED WATER PUMP	CP	2	25 HP	480/3/VAR	LEVEL 0 MECH RM	-	VFD	-	BNH1	CB	70A/3P	6	10	3/4"	6
CHILLED WATER PUMP	CP	3	2 HP	480/3/1	LEVEL 01 AREA A	HOA-P	COMB	1	1NH2	CB	15A/3P	12	12	3/4"	
CHILLED WATER PUMP	CP	4A	1/6 HP	120/1/1	LEVEL 04 - LAB 489	P	MS	0	4LL2	CB	20A/1P	12	12	3/4"	
CHILLED WATER PUMP	CP	4B	1/6 HP	120/1/1	LEVEL 04 - LAB 489	SAME AS CP-4A	SAME AS CP-4A	SAME AS CP-4A	4LL2	CB	20A/1P	12	12	3/4"	
CONDENSING UNIT	CU	1	46 MCA	480/3/1	ON GRADE	-	PWCP	-	1SH1	CB	60A/3P	6	10	3/4"	2, 4
CONDENSING UNIT	CU	2	46 MCA	480/3/1	ON GRADE	-	PWCP	-	1SH1	CB	60A/3P	6	10	3/4"	2, 4
CABINET UNIT HEATER	CUH	101	40 WATT	120/1/1	LEVEL 01 - VEST C153	-	PWCP	-	1NL1	CB	15A/1P	12	12	3/4"	1, 4
CABINET UNIT HEATER	CUH	102	40 WATT	120/1/1	LEVEL 01 STAIR 2-1	-	PWCP	-	1NL2	CB	15A/1P	12	12	3/4"	1, 4
CABINET UNIT HEATER	CUH	201	40 WATT	120/1/1	LEVEL 02 - VEST C250A	-	PWCP	-	2NL1	CB	15A/1P	12	12	3/4"	1, 4
CABINET UNIT HEATER	CUH	202	40 WATT	120/1/1	LEVEL 02 - VEST C230A	-	PWCP	-	2NL1	CB	15A/1P	12	12	3/4"	1, 4
CABINET UNIT HEATER	CUH	203	40 WATT	120/1/1	LEVEL 02 - C270A EAB CONNECTOR	-	PWCP	-	2NL1	CB	15A/1P	12	12	3/4"	1, 4
CABINET UNIT HEATER	CUH	204	40 WATT	120/1/1	LEVEL 02 - C270A EAB CONNECTOR	-	PWCP	-	2NL1	CB	15A/1P	12	12	3/4"	1, 4
D.I. WATER SYSTEM	DI	1	5 HP	480/3/VAR	LEVEL 00 AREA A	-	PWCP	-	BNH1	CB	15A/3P	12	12	3/4"	
EXHAUST FAN	EF	1	3 HP	480/3/1	ROOF	HOA-P	COMB	1	4SH1	CB	15A/3P	12	12	3/4"	1, 2
EXHAUST/RELIEF FAN	EF	2	7.5 HP	480/3/VAR	ROOF	-	VFD	-	4NH1	CB	20A/3P	12	12	3/4"	1, 6
EXHAUST FAN	EF	3	3 HP	480/3/VAR	ROOF	-	VFD	-	4NH1	CB	15A/3P	12	12	3/4"	1, 6
EXHAUST FAN	EF	4	1/2 HP	120/1/1	ROOF	-	MS	0	4NL1	CB	20A/1P	12	12	3/4"	
ELEVATOR SUMP PUMP	ESP	1	.72 KW	120/1/1	ELEVATOR PIT 1	-	-	-	1NL1	CB	20A/1P	12	12	3/4"	
ELEVATOR SUMP PUMP	ESP	2	.72 KW	120/1/1	ELEVATOR PIT 2	-	-	-	BNL1	CB	20A/1P	12	12	3/4"	
ELECTRIC WATER COOLER	EWC	1	.37 KW	120/1/1	LEVEL 01 AREA A	-	-	-	1NL1	CB	20A/1P	12	12	3/4"	
ELECTRIC WATER COOLER	EWC	2	.37 KW	120/1/1	LEVEL 02 AREA A	-	-	-	2NL1	CB	20A/1P	12	12	3/4"	
ELECTRIC WATER COOLER	EWC	3	.37 KW	120/1/1	LEVEL 03 AREA A	-	-	-	3NL1	CB	20A/1P	12	12	3/4"	
ELECTRIC WATER COOLER	EWC	4	.37 KW	120/1/1	LEVEL 04 AREA A	-	-	-	4NL1	CB	20A/1P	12	12	3/4"	
FAN COIL UNIT	FCU	1	0.1 kW	208/1/1	LEVEL 01 - DATA CLOSET	-	PWCP	-	1NL1	CB	15A/2P	12	12	3/4"	4, 8
FAN COIL UNIT	FCU	2	0.1 kW	208/1/1	LEVEL 02 - DATA CLOSET	-	PWCP	-	2NL1	CB	15A/2P	12	12	3/4"	4, 8
FAN COIL UNIT	FCU	3	0.1 kW	208/1/1	LEVEL 03 - DATA CLOSET	-	PWCP	-	3NL1	CB	15A/2P	12	12	3/4"	4, 8
FAN COIL UNIT	FCU	4	0.1 kW	208/1/1	LEVEL 04 - DATA CLOSET	-	PWCP	-	4NL1	CB	15A/2P	12	12	3/4"	12
FAN COIL UNIT	FCU	5A	0.1 kW	208/1/1	LEVEL 01 - MDF ROOM	-	PWCP	-	1NL2	CB	15A/2P	12	12	3/4"	4, 8, 10
FAN COIL UNIT	FCU	5B	0.1 kW	208/1/1	LEVEL 01 - MDF ROOM	-	PWCP	-	1NL2	CB	15A/2P	12	12	3/4"	4, 8, 10
FAN COIL UNIT	FCU	5C	0.1 kW	208/1/1	LEVEL 01 - MDF ROOM	-	PWCP	-	1NL2	CB	15A/2P	12	12	3/4"	4, 8, 10

- (1) CONTROLLER DATA ACCESSORIES**
HOA - HAND-OFF-AUTO SWITCH MAINTAINED
HLOA - HIGH-LOW-OFF AUTO SELECTOR SWITCH OR PUSHBUTTON
P () - PILOT LIGHT (QUANTITY) - SEE SPECIFICATION FOR COLOR OF LIGHTS
- SS - START-STOP PUSHBUTTON MAINTAINED CONTACT SELECTOR SWITCH OR PUSHBUTTON
SSM - START-STOP MOMENTARY CONTACT
TDR - TIME DELAY RELAY
SPEC - SEE SPECIFICATION SECTION 235000
- (2) CONTROLLER DATA TYPE (DIVISION 26 UNLESS OTHERWISE NOTED)**
VFD - VARIABLE FREQUENCY DRIVE
COMB - COMBINATION FVNR STARTER WITH FUSIBLE DISCONNECT SWITCH
CONTR - CONTACTOR
PF - PLUG FUSE SWITCH
MS - MANUAL STARTER
TSS - TWO-SPEED STARTER
FVNR - FULL VOLTAGE NON-REVERSING STARTER
FVR - FULL VOLTAGE REVERSING STARTER
RVNS - REDUCED VOLTAGE NON-REVERSING STARTER
SSS - SOLID-STATE STARTER
PWCP - PRE-WIRED CONTROL PANEL (FURNISHED WITH DIVISION 23 EQUIPMENT)
- (3) BRANCH CIRCUIT DEVICE TYPE**
CB - CIRCUIT BREAKER
FS - FUSIBLE SWITCH

- GENERAL NOTE:
OVER CURRENT PROTECTION BASED ON ENERGY EFFICIENT MOTOR DATA FOR HORSEPOWER THROUGH 40 HORSEPOWER UNLESS OTHERWISE NOTED.
- KEYED NOTES:
- EQUIPMENT FURNISHED WITH INTEGRAL DISCONNECT SWITCH.
 - EMERGENCY POWER REQUIRED.
 - MULTIPLE MOTORS ON ONE DRIVE. DRIVE PROVIDED AND WIRED ON THE LOAD SIDE BY THE EQUIPMENT MANUFACTURER.
 - SEE SPECIFICATIONS FOR CONTROLLER REQUIREMENTS.
 - EQUIPMENT FURNISHED WITH CORD AND PLUG. 20 AMP CIRCUIT REQUIRED.
 - VARIABLE FREQUENCY DRIVE BY DIVISION 23.
 - EQUIPMENT FURNISHED WITH INTEGRAL LIGHT FIXTURES FURNISHED AND MOUNTED BY DIVISION 23. DIVISION 26 TO PROVIDE ALL BRANCH CIRCUIT WIRING AND CONDUIT FOR CONNECTION OF FIXTURES AND LIGHT SWITCH AT ENTRY TO UNIT. REFER TO DIVISION 23 DRAWINGS AND SPECIFICATIONS FOR FIXTURE TYPES.
 - FAN COIL AIR CONDITIONERS FOR IT-DATA CLOSETS AND MDF ROOM. FAN COIL UNITS (FCU) SHALL BE WIRED BACK TO ASSOCIATED AIR-COOLED CONDENSING UNIT (ACCU).
 - VENTILATION FAN FOR ELEVATOR MACHINE ROOM.
 - MULTIPLE PIECES OF EQUIPMENT ON THE SAME CIRCUIT BREAKER/DISCONNECT SWITCH.
 - MULTIPLE POWER CONNECTIONS FOR AN INDIVIDUAL PIECE OF EQUIPMENT.

THE SEAL(S) AND SIGNATURE(S) APPLY ONLY TO THE DOCUMENT TO WHICH THEY ARE AFFIXED, AND EXPRESSLY DISCLAIM ANY RESPONSIBILITY FOR ALL OTHER PLANS, SPECIFICATIONS, ESTIMATES, REPORTS OR OTHER DOCUMENTS OR INSTRUMENTS RELATING TO OR INTENDED TO BE USED FOR ANY PART OR PARTS OF THE ARCHITECTURAL OR ENGINEERING PROJECT.



Webster University
Interdisciplinary Science Building

CANNONDESIGN

1100 Clark Avenue
St. Louis, Missouri 63102
T: 314.241.6250
F: 314.241.2570

William Tao & Associates, Inc.
MEP/FP Engineer
7955 Manchester Road, Suite 125
St. Louis, MO 63143
314-884-7600

David Mason & Associates, Inc.
Structural & Civil Engineer
800 South Vandeventer Avenue
St. Louis, MO 63110
314.534.1053

Faith Group
Technology
3101 S. Hanley Rd., Suite 100
St. Louis, MO 63143
314.591.2235

Kuhlmann Leavitt, Inc.
Environmental Graphics & Signage
7400 Pershing Ave.
St. Louis, MO 63130
314.725.6616

KWA Architects
Architecture
8721 Litzinger Road
St. Louis, MO 63124
314.962.2560

Spellman Brady & Company
Interior Designer
8251 Maryland Avenue, Suite 300
St. Louis, MO 63105
314.862.0070

SWT Design
Landscape Architect
7722 Big Bend Blvd
St. Louis, MO 63119
314.644.5700

Webb Engineering Services, Inc.
Planning & Fire Protection
1400 S. 3rd Street, Suite 201
St. Louis, MO 63104
314.558.0600

CONFORMED SET 01 JUL 2016

2	ADDENDUM 2-2	19 APRIL 2016
1	ADDENDUM 2-1	17 MAR 2016
-	ISSUED FOR CONSTRUCTION (BP2)	01 MAR 2016
No.	Description	Date

Drawing Title:

EQUIPMENT DATA
SCHEDULE

Project No.: 04561.01 Checked by:

ME0003

© Cannon Design 2015