



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: February 26, 2016	NO.: RFI-007
--------------------------------	--------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Using one layer of waterproofing in lieu of two

Response Required By: March 04, 2016

Drawing / Spec Reference:

Information Requested:

071326 - 3.3D calls for a two ply application of waterproofing. This is not typical for such applications and is normally done with one layer.

Suggestion: Paric proposes to use one layer which will result in an owner's savings of \$43,900.

Response:

Based on the Owner's comment, Contractor shall install one layer of self adhering sheet waterproofing installed in compliance with the manufacturer's published installation instructions.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kathy Williams

Date: March 4, 2016