



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: March 02, 2016	NO.: RFI-009
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Requesting additional civil clarifications

Response Required By: March 09, 2016

Drawing / Spec Reference:

Information Requested:

1. Please confirm if the existing 8" PVC sanitary line which connects to the southeast corner of the stucco building can be taken out of service for demo.
2. We are requesting to have DM&A overlay the Castle GPS as-builts on the site improvement plan for coordination.
3. We are requesting to have DM&A place the proposed building limits on the existing conditions drawing for coordination

Response:

1. Coordinate removal of existing sanitary sewer to stucco building with Webster University.
2. & 3. These drawings will be provided after MSD approval, design modifications are on going.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark Davis, David Mason and Associates

Date: March 7, 2016