



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: March 17, 2016	NO.: RFI-015
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Sound batt insulation at mullions

Response Required By: March 24, 2016

Drawing / Spec Reference:

Information Requested:

The architectural drawings and spec 084423 section 2.2A-3 call for sound batts at mullions. Please provide specific product and manufacturers for bid purposes.

Response:

Provide unlaced mineral wool blanket insulation complying with specification section 072100 paragraph 2.3.A. Curtain wall manufacturer / fabricator to verify that performance requirements of system are not affected

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 03.24.16