



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: March 28, 2016 NO.: RFI-022

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Integrated power equipment specifications

Response Required By: April 04, 2016

Drawing / Spec Reference:

Information Requested:

E0501 - keyed note 4 calls out integrated units. There are no specifications provided regarding teh equipment. Will specifications be provided?

Suggestion: Please advise. BP-2 pre-bid RFI.

Response:

Specifications will not be provided. All integrated units shall be equal to Eaton - Integrated Facility System (IFS).
Bill Shaw, WTA 3/29/16

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: _____

Date: _____