



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: March 29, 2016	NO.: RFI-024
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Alternate Laclede Gas meter location

Response Required By: April 05, 2016

Drawing / Spec Reference:

Information Requested:

As a follow up to RFI 12, please see attached correspondence from Laclede Gas.

Suggestion: Please advise if another meter pad location can be found to allow the fuel run to not be installed below the sidewalk.

Response:

No other locations available for gas meter. However, per our meeting with Laclede gas (4-14-2016) the gas line from the meter to the building will be located in a trough that is accessible. This was approved by Laclede and civil/structural/mechanical drawing modifications reflecting this change will be issued in addendum.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark Schaefer

Date: 4-18-2016