



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** April 06, 2016 **NO.:** RFI-026

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Pier cap reinforcement clarification

Response Required By: April 13, 2016

Drawing / Spec Reference:

Information Requested:

"The pier cap schedule shown on S0004 calls for #5 horizontal reinforcing steel and #6 vertical reinforcing steel. The notes on the vertical steel call for #6 U bars at 10" o.c. top only. The typical detail 3/S0003 for the pier cap shows a top & bottom bar for vertical but has you refer to the schedule.

Suggestion: Please clarify if the #6 vertical bars are to be top and bottom or top only reinforcing.

Response:

Provide #6 vertical bars in pairs for top and bottom reinforcing.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Jill Walker / DMA

Date: 4/6/2016