



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: April 11, 2016 NO.: RFI-030

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Paint color sample

Response Required By: April 18, 2016

Drawing / Spec Reference:

Information Requested:

Please provide color chips of the selected aint finish for the exterior aluminum curtain wall so that it may be matched with a kynar finish and color samples can be issued for approval.

Response:

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

The sample we are trying to match is Reynobond - Colorweld 500 - Pewter.

The sample we have is from Alcoa Architectural Products RB4CW5PWT 11/15/13.

Answered By: Lynn Grossman

Date: 04.12.16