



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: April 18, 2016	NO.: RFI-038
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Additional BP 3 clarifications

Response Required By: April 25, 2016

Drawing / Spec Reference:

Information Requested:

Spec 098413 is for the Wood Acoustical Panels but on ID0203 under 098413 is listed FAP-1 which is a Fabric Wrapped Panel. There is no spec for that product other than the Material Finish Legend.

G&S Panel is listed in the Finish Legend under 098414 – Stretched Fabric Systems. No such spec # in the spec book.

Clipso is listed in 097713 – also called Stretch Fabric System – but the Material Legend does not list and we cannot find any designation for this product on the plans.

Suggestion: Please clarify.

Response:

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

[For FAP-1 and AP-1, use specification section 098433 Sound Absorbing Wall Units.](#)
[Use 097713 for the stretched fabric indicated on 1/A0602](#)

Answered By: [Lynn Grossman](#)

Date: [04.19.16](#)