



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: April 28, 2016 NO.: RFI-049

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Pilaster height at B.3/6 line

Response Required By: May 05, 2016

Drawing / Spec Reference:

Information Requested:

S100 shows the PC1 at 67' but does not address the pilaster. Details 8 and 9/200 do not identify the pilaster height. The column schedule on S0501 B.3-6 shows the 24" x 24" pilaster is shown below the 86' elevation but does not identify an elevation.

Suggestion: Please provide.

Response:

T/Pilaster @ B.3-6 = 85'-0"

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Jill Walker / DMA

Date: 4/28/2016