



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: April 29, 2016	NO.: RFI-051
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Addendum 1-8 DBS clarification

Response Required By: May 06, 2016

Drawing / Spec Reference:

Information Requested:

Addendum 1-8 shows a DBS @ 12" OC which appears to butt up directly to the BT PL 3/8"x2 1/2" x 6". Is the design intent for this DBS to be welded to the bent plate?

Suggestion: Please clarify.

Response:

Yes.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: JILL WALKER / DMA

Date: 5/9/2016