



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: May 02, 2016	NO.: RFI-053
--------------------------------	---------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: BP 3 - prebid glass questions

Response Required By: May 09, 2016

Drawing / Spec Reference:

Information Requested:

1. Per the door schedule the frames around Doors 140.2 & 174 call for GLI-4 which is listed as 5/8" Clear Monolithic. NGG has priced this as 1/2" Monolithic Glass, because of 5/8" glass scarcity & because 1/2" glass meets deflection criteria. Please confirm if this is acceptable or if other pricing is needed
2. Glass Specifications 088000 2.14 J & K list GLI 9 & GLI 10. These are not found in the plans. Please confirm.
3. Door Schedule calls for framing around door 235 to be GLI-14. This glass make-up is not found in the specification. Please clarify.
4. Please confirm use of perimeter caulking on details 6/A0842, 3/A0841, 8/0810.

Response:

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Responses to these questions are in RFI 52.

Answered By: _____

Date: _____