



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: May 11, 2016	NO.: RFI-067
--------------------------------	---------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Ceiling at rooms 178 and 188

Response Required By: May 18, 2016

Drawing / Spec Reference:

Information Requested:

The hard ceilings in rooms 178 and 188 are shown at 11'-9". This elevation will not work due to the fire protection, hvac, plumbing, lights, bracing, etc.

Suggestion: Paric proposes to eliminate ceiling in both rooms.

Response:

This ceiling cannot be eliminated, it is needed for sound isolation of the noise generated by the mechanical equipment.
The ceiling can be lowered or raised and wrapped around beams if current elevations do not work.
Please coordinate and propose a ceiling elevation that works.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 05/17/2016