



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: May 11, 2016	NO.: RFI-073
--------------------------------	---------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Floor drain locations in cadaver lab

Response Required By: May 18, 2016

Drawing / Spec Reference:

Information Requested:

Please confirm that the two floor drain locations in room 191 Cadaver Lab have been coordinated with future cadaver tables and equipment.

Response:

The floors drains and floor clean-outs are to be relocated.
This will be addressed in an up-coming addendum.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mike Whitworth - WES

Date: May 18, 2016