



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: May 12, 2016	NO.: RFI-079
--------------------------------	---------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Sanitary in MDF room

Response Required By: May 19, 2016

Drawing / Spec Reference:

Information Requested:

Plumbing sheet P0111.A shows a 2" sanitary line routed through the ceiling of the MDF room. This sanitary line serves a lab sink on Level 02 above, and cannot be moved. There are no notes on the plans or in the specifications on what measures are required for this condition. Please advise what should be done (if anything) with this line located in the MDF room.

Response:

A galvanized sheet metal drip pan will be required,
This will be addressed in an up-coming addendum.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mike Whitworth - WES

Date: May 13, 2016