



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 17, 2016 **NO.:** RFI-091

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: shear stud length at slabs

Response Required By: May 24, 2016

Drawing / Spec Reference:

Information Requested:

Please confirm the shear stud length(s) to be used on this project at both the 6 ½" and the 4 ½" thick slabs.

Atlas' comment:

- ~~S0001 'COMPOSITE BEAM' Note #1 calls for 4" long (after welding) shear studs~~
- 20/S0002 calls for 5" studs at the 6 ½" slabs and 3 ½" studs at the 4 ½" slabs (see recessed slab area on S0104, near C-7)

Response:

FOLLOW 20/S0002.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: **JILL WALKER / DMA**

Date: **5/25/2016**