



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: May 17, 2016	NO.: RFI-092
--------------------------------	---------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Additional steel fabrication clarifications

Response Required By: May 24, 2016

Drawing / Spec Reference:

Information Requested:

On 10/S0003 please advise the size of the rectangular web openings.

On 2/S0101 and 18/S0200 please advise if the embed L4x4x3/8 is required at the north and south sides of the slab at el 90'. Please verify that this embed angle will not be required across the head of the concrete steps.

Response:

OPENING SIZE IS 12" WIDE BY 5" TALL.

L4X4 IN 17&18/S0200 IS NOT REQ'D ON THE NORTH, SOUTH, AND ALONG THE HEAD OF THE STEPS. L4X4 IS TO RUN FROM SOUTHWEST CORNER TILL MEETS THE SOUTH SIDE OF THE STEPS.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

JILL WALKER / DMA

5-27-2016

Answered By: _____

Date: _____