



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: May 18, 2016	NO.: RFI-093
--------------------------------	---------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Parameters for attaching to roof deck

Response Required By: May 25, 2016

Drawing / Spec Reference:

Information Requested:

To finalize equipment hanger design please provide "pullout requirements" for hanging from the metal deck roofing.

Response:

**"DO NOT SUSPEND PIPES OR DUCTS FROM ROOF DECK" PER
GENERAL NOTES. PROVIDE MORE SPECIFIC INFORMATION.**

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: JILL WALKER / DMA

Date: 2/9/2016