



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 18, 2016 **NO.:** RFI-095

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Venting for Level 0 underground

Response Required By: May 25, 2016

Drawing / Spec Reference:

Information Requested:

There are currently no vents shown on the underground sanitary piping on sheet P0010 serving Level 0 floor drains. Please confirm that no vents are required on the floor drains, as there may be impacts on the p-trap seals.

Response:

Sanitary vents have been added to the Level 0 floor drains.
An electronic trap primer system has also be included.
This is addressed in an up-coming addendum.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: May 20, 2016