



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 19, 2016 **NO.:** RFI-097

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Confirm mixing valve for ES-1

Response Required By: May 26, 2016

Drawing / Spec Reference:

Information Requested:

Specification for ES-1 (Emergency Eyewash/shower combination unit) calls out to supply this fixture with water from mixing valve TMV-3. However, this mixing valve only has 1/2" inlets and outlets. This does not appear to be sufficient water volume to supply ES-1 with. Please confirm TMV-3 is the desired mixing valve to supply ES-1.

Response:

Emergency shower ES-1 is to be provided with thermostatic mixing valve TMV-2.
Emergency eye wash 'EW-1' is to be provided with thermostatic mixing valve 'TMV-3'
TMV-2 was misidentified in the Plumbing Fixture Schedule on drawing P0601, under the description for the Emergency Shower, this has been corrected. The description for TMV-2 does identify this is to be provided with ES-1, as does the various piping details, diagrams and floor plans.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: May 20, 2016