



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 19, 2016 **NO.:** RFI-098

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Mounting heights for plumbing fixtures

Response Required By: May 26, 2016

Drawing / Spec Reference:

Information Requested:

There are only mounting heights provided for some of the plumbing fixtures. Please provide mounting heights for all plumbing fixtures as well as dimensions from the side wall to the unit for coordination.

Response:

This RFI is vague.
Refer to architectural drawing A0002. Plumbing fixtures are to be installed at 'standard' mounting heights and clearances. Those designated as ADA are to be installed at ADA compliance heights and clearances.
If there is a specific fixture in question identify that fixture for clarification.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: May 20, 2016