



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 19, 2016 **NO.:** RFI-099

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Plumbing fixtures at room 174

Response Required By: May 26, 2016

Drawing / Spec Reference:

Information Requested:

Sheet A0202, Detail 2 calls out an ADA double bowl sink with garbage disposer in Room 174. The Plumbing specification for this fixture on Sheet P0601 (KS-2) does not call out for an ADA insulation kit to be provided for this fixture. Also, the waste piping components for KS-2 do not appear to allow ADA access for this sink.

- 1) Please advise where the disposer is to be mounted at this sink.
- 2) Please verify if an ADA insulation kit is required for the plumbing fixtures in this room.
- 3) Please verify if the waste piping specified for the ADA sinks in this room is correct as currently specified.

Response:

1. The garbage disposer indicated has been removed from the plumbing drawings. Refer this question to the Architect or Kitchen Consultant for disposition of the unit.
2. ADA compliant protective covers is required for all exposed/accessible piping below the sink. A product such as Lav Guard 2 or an approved equal is acceptable.
3. The waste piping for each fixture shall be as required for its intended use and designation, ADA or Non-ADA and accessibility. Refer to the architectural drawings and/or the kitchen consultant drawings for cabinet construction and installation details.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: May 21, 2016