



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 19, 2016 **NO.:** RFI-101

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Mounting heights for emergency fixtures

Response Required By: May 26, 2016

Drawing / Spec Reference:

Information Requested:

Question: Please provide mounting heights for typical emergency/shower combination unit (both shower head and control panel) based off of finish floor.

Response:

Mounting height and installation of the combination emergency shower/eye wash unit is to be in full compliance with ANSI Z358.1 requirements, ADA compliance, the authority having jurisdiction and the manufacturers recommendations, based on the governing guidelines for the unit selected. This information is generally indicated on the manufacturers cut-sheet and unit installation manual. Coordinate installation clearances with the Architect.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: **Mike Whitworth - WES**

Date: **May 21, 2016**