



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 19, 2016 **NO.:** RFI-103

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: vent for loading dock floor drain

Response Required By: May 26, 2016

Drawing / Spec Reference:

Information Requested:

The Floor Drain in the loading dock just North of B-line, between 7 and 7.1 line, is shown on sheet P0011 without any vent piping. Please confirm that this floor drain is to be connected to the sanitary system without a vent. If a vent is required, please advise where it is to connect to the vent system.

Response:

This floor drain will be vented.
This will be addressed in an up-coming addendum.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: May 21, 2016