



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 24, 2016 **NO.:** RFI-107

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Details at brick screen wall

Response Required By: May 31, 2016

Drawing / Spec Reference:

Information Requested:

Note 31 on C-400 calls to remove and replace existing brick screen wall. Please see attached photos regarding the following questions;

1. Verify if the new wall is to match the existing width. Currently this is just two bricks wide, back to back at 8 1/4" total.
Intent is to match existing wall width. It will be composite brick wall - solid grouted with rebar. Details will be issued in future addendum.
2. Verify if there is to be a limestone cap installed to match.
Yes there will limestone cap installed to match existing. Intent is to match existing wall.
3. Verify if the same profile is to be used at the top and bottom of the new wall. Wall currently "flares out" at the top and bottom.
Intent is to match existing profile.
4. Verify if there are any additional details needed at pilasters and if we are to match existing pilaster spacing. Pilasters are currently 13" thick.
Intent is to match existing pilaster spacing and details. Additional details will be issued in future addendum.
5. Please confirm the intent is to remove the wall back to the next pilaster past what is shown on the demo plan.
Yes. Verify if the MAWC easement requires removal of additional wall.
6. The brick currently follows the slope of the existing grade. Please confirm if the intent is for the new wall to have level horizontal joints or to follow grade. If the intent is to have level horizontal joints the footing will need to be designed to step down with grade.
Intent is for the new wall to follow grade similar to existing wall.

Response:

**See responses in red color text above.
Details will be issued in future addendum.**

Answered By: Kelvin Patel

Date: 05/25/2016



ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: _____

Date: _____



