



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 26, 2016 **NO.:** RFI-110

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Drain quantities at area B, level 2

Response Required By: June 02, 2016

Drawing / Spec Reference:

Information Requested:

Sheet A0423 shows six pair of primary/overflow drains in the paver area of Level 02, Area B. The plumbing drawings only show five pair. Please advise if an additional primary/overflow drain and associated piping should be added to the plumbing system to match the quantities shown on sheet A0423.

Response:

Two roof drains and two overflow drains will be added to the plumbing drawings at the locations shown on architectural drawing A0423, detail 4.
This will be addressed in an up-coming addendum.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: June 01, 2016S