



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 27, 2016 **NO.:** RFI-117

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: ADA Sink Locations

Response Required By: June 03, 2016

Drawing / Spec Reference:

Information Requested:

Reference RFI 72, please advise locations of ADA and non ADA sinks

Response:

Sink SK-1 Break Rooms: ADA Compliant.
Sink SK-2 Nursing Mock Exam and Lact. (275): ADA Compliant.
Sink SK-3 Nursing Class/Lab: Sink is integral with the counter top. Confirm requirements with the architect.
Kitchen Sink KS-1 Teaching Kitchen: Non-ADA.
Kitchen Sink KS-2 Teaching Kitchen: ADA Compliant.
Kitchen Sink KS-3 Teaching Kitchen: Non-ADA.
Refer to the architectural drawing series A020X for the Lab Utility Legend for information concerning and relating to sinks in Laboratories and related spaces.
Provide off-set waste connections and piping protective covers where required For ADA compliant installations.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: June 06, 2016