



**PARIC CORPORATION**  
77 Westport Plaza Suite 250  
St. Louis, MO 63146  
TEL: 636-561-9500  
FAX: 636-561-9501

---

**REQUEST FOR INFORMATION      DATE: May 27, 2016      NO.: RFI-118**

---

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building      Project No.: 15051

Subject: Using GL-5 as submitted

Response Required By: June 03, 2016

Drawing / Spec Reference:

**Information Requested:**

Due to the manufacturing limitations of Virracon please confirm GL-5 will be accepted as submitted or provide alternate specifications

**Response:**

**ARCHITECT'S RESPONSE:**

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Glass Type **GLE-5** is acceptable as submitted and received from Viracon:

1 5/16" Clear/VNE - 63 Laminated Glass

1/4" clear HS

.060 PVB clear

1/4" clear HS

VNE-63 #4

1/2" airspace-black

black silicone

1/4" Clear HS. (Where required provide tempered interior light per 088000 1.3D).

Answered By: Lynn Grossman

Date: 05.27.16