



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: May 27, 2016 NO.: RFI-119

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Maximum concrete temperature

Response Required By: June 03, 2016

Drawing / Spec Reference:

Information Requested:

Specifications call for a maximum allowable temperature of concrete to be 90 deg F. ACI specs now state 95 deg F are acceptable. Please confirm 95 deg F will be acceptable.

Response:

PER THE RECENT CHANGES CONTAINED IN ACI 301-10, MAXIMUM TEMPERATURE MAY BE INCREASED TO 95 DEG AND ANY ADDITIONAL REQUIREMENTS FOR SAME SHALL BE PER ACI 301-10 TO MAINTAIN CONSISTANT REQUIREMENTS.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: **JILL WALKER / DMA**

Date: **6/3/2016**