



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: May 27, 2016	NO.: RFI-126
--------------------------------	---------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Details for HPS umbilical connection trench

Response Required By: June 03, 2016

Drawing / Spec Reference:

Information Requested:

10/A0611 shows a trench for the HPS umbilical connections in the slab. Please provide additional details including size, shape, plan dimensions, and reinforcement details.

Response:

Attached is a detail showing additional information on the trench and cover plate. This will be issued with a future ASI. Please note that S101 calls out reinforcing.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Lynn Grossman

Date: 06.21.16

