



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 31, 2016 **NO.:** RFI-129

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Coverage at light hazard

Response Required By: June 07, 2016

Drawing / Spec Reference:

Information Requested:

Spec 211313 – 2.1, C, 5, A calls for a maximum area of 120 sq ft design for office and public areas which are Light Hazard. Section 4 also states the maximum protection area is according to sprinkler listing. NFPA code for standard coverage heads allow for 225 sq ft maximum spacing. Ahern Fire would like to confirm the design intent is Light Hazard with a maximum of 225 sq ft.

Response:

The fire suppression system is a delegated design submittal. The contractor is responsible for a complete system design in accordance with FM Global, NFPA and the Authority Having Jurisdiction. The area of coverage for sprinkler heads shall be within their listings, acceptance and approvals by the governing agencies. Where use, areas of coverage or densities differ between NFPA, FM Global and AHJ, the most stringent shall apply.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: June 02, 2016