



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 31, 2016 **NO.:** RFI-130

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Hose valve finish

Response Required By: June 07, 2016

Drawing / Spec Reference:

Information Requested:

1. Spec 211200 - 2.7, A, 9 shows the finish of individual hose valves as polished chrome. With the fire department connection and fire pump test header the Fire protection contractor understands the aesthetics of the polished chrome standard. All hose valves within the building are either exposed on black piping or contained within hose cabinets.

Suggestion: Fire Protection Contractor proposes to provide standard rough brass finish. Please verify.

Response:

Prior to accepting or denying this, please indicate the credit that will accompany this change.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth

Date: June 04, 2016