



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 31, 2016 **NO.:** RFI-131

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Extended coverage heads

Response Required By: June 07, 2016

Drawing / Spec Reference:

Information Requested:

Drawings and specifications reference the use of extended coverage heads. Is the Fire Protection contractor free to utilize extended coverage heads to assist in coordination by minimizing branch line piping? Please confirm.

Response: The fire suppression system is a delegated design submittal. The contractor is responsible for a complete system design in accordance with FM Global, NFPA and the Authority Having Jurisdiction. The utilization of extended coverage sprinkler heads is acceptable when and where they are used within their listings, acceptance and approvals by the governing agencies.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: June 02, 2016