



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 31, 2016 **NO.:** RFI-132

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Sprinkler Finish

Response Required By: June 07, 2016

Drawing / Spec Reference:

Information Requested:

Drawing and specifications conflict as to sprinkler finish. Fire Protection Contractor's intent is to provide:

Uprights/Pendants in exposed areas – Brass Finish
Semi-Recessed Pendants and HSWs – Chrome Finish
Concealed – Plate in White Finish

Please confirm.

Response:

Upright/Pendant - Brass finish in unfinished areas and areas not open to the public.
Finished areas and areas open to the public shall have chrome finish.

Semi-Recessed Pendants and WSW's - Chrome finish.

Concealed - Generally a white finish plate will be acceptable. Select areas may require a different color selection or custom finish as determined by the Architect.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: June 02, 2016