



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 31, 2016 **NO.:** RFI-133

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building

Project No.: 15051

Subject: 8" Water Service Clarificaion

Response Required By: June 07, 2016

Drawing / Spec Reference:

Information Requested:

Contract Drawing FP0101.A Keyed Note 1 states Fire Protection starting from an 8" service up through the floor from Level 0. Current plumbing drawings show the service coming across Level 1 leaving the tee separating service above the ceiling of the Fire Pump Room 188. Please confirm correct configuration

Response: { The combination domestic / fire water service as shown on plumbing drawing P0101.A is correct.
Fire protection drawing FP0101.A will be corrected. }

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: June 02, 2016