



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** June 01, 2016 **NO.:** RFI-136

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Louver opening dimension

Response Required By: June 08, 2016

Drawing / Spec Reference:

Information Requested:

A0101.EA (rev.1 , Addm 1-9) shows this opening as 28'-5" (starting 1'-1" south of line E)

1/A0313 (rev. 3, addm 1-11) shows the louver opening starting 1'-0" south of line E, leaving a 28'-6" opening. (See the dimensions on 1/A0313, below Level 01, lines D to E)

Please clarify this opening dimension for the 'frame' on S0103, line 8, D to E (sections 1 & 2/S0301)

Response:

Sheet A0101.EA (rev.1, addm 1-9") is correct. Louver opening should be 1'-1" south of column line E. Opening should be 28'-5". 1/A0313 Rev. 3, addm 1-11) the dimension 1'-0" should be deleted. bottom of steel shall be 8'-0" above level 1 for the shelf angle. The louver opening would be 28'-5" x 6'-6"

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: _____

Date: 06/03/16