



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** June 01, 2016 **NO.:** RFI-138

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Drain Tile Basin

Response Required By: June 08, 2016

Drawing / Spec Reference:

Information Requested:

Reference addendum 2-4. The Drain tile system drains into a Duplex sump basin plan marked SP-1. This is a duplex system in a single basin per detail #8 on P0501. On sheet P0010, the drawing shows SP-1 with a note saying "Typ/2". Please confirm there is only (1) 36" basin with 2 SP's per detail P0501 and not (2) 36" basins with (2) SP-1's each for a total of (4) SP-1 pumps.

Response:

There is one sump pit and two sump pumps, SP-2 and SP-2.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: June 01, 2016S