



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 01, 2016 NO.: RFI-139

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Stainless steel flashing at curtainwall

Response Required By: June 08, 2016

Drawing / Spec Reference:

Information Requested:

2/A0455 and 5/A0455 call for 26 GA stainless steel flashing. Please confirm if these are to be a stainless or painted finish.

Response:

Stainless steel flashing to be fluoropolymer coated with color matched to curtain wall mullions.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: **Kelvin Patel**

Date: **06/03/2016**