



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 01, 2016 NO.: RFI-140

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Drain tile for site Retaining walls

Response Required By: June 08, 2016

Drawing / Spec Reference:

Information Requested:

Details 4 & 5 on S003 and 4/S004 indicate drain tile at the base of the wall. The plumbing drawings and Civil drawings do not indicate any drain tile piping at these wall locations. Please advise if the drain tile is required, or if the Civil and Plumbing drawings should be followed for drain tile scope.

Response:

Drain tile is required, connect to building drain tile system.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mark Davis, David Mason and Associates

Date: June 3, 2016