



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 01, 2016 NO.: RFI-142

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: E0102.A floor box clarification

Response Required By: June 08, 2016

Drawing / Spec Reference:

Information Requested:

On sheet E0102.A Note 64 calls for a 4 gang floor box but utilizes a 2 gang floor box part number. Should this be a (2) gang or (4) gang floor box ?

Response: Yes, keyed note E64 is for a 4 gang box (RFB4S)

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: **Bill Shaw**

Date: **06/03/2016**
