



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 03, 2016 NO.: RFI-149

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Ceiling at 178

Response Required By: June 10, 2016

Drawing / Spec Reference:

Information Requested:

S103 note 6 calls for a 99' 5 1/2" inch top of structural steel. There is a W27 x 84 beam along 8 line which will have a bottom of steel elevation of 97' 2 1/2". This is 11' 2 1/2" above finish floor. A0701 calls for 11' 9 1/2" and this is likely to need to be at 11'6" AFF after coordination is finished. Mechanical equipment will not allow this ceiling to be lower.

Please advise if the design intent is for the W27 beam to be exposed or provide details if the intent is for this to be covered.

Response:

The design intent is to cover the W27x84 beam along grid line 8.
Wrap the steel beam with 2-layers of gyp. board for continuous sound isolation.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Lynn Grossman & Kelvin Patel

Date: 06/15/2016