



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 06, 2016 NO.: RFI-152

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Curtainwall mockup clarifications

Response Required By: June 13, 2016

Drawing / Spec Reference:

Information Requested:

On elevation #2 of the mock-up the reviewer commented that this opening was to have the EGS-2 aluminum system. On sheets M16 the comment indicates a 5 1/2" system. EGS-2 is neither of those dimensions. EGS-3 is specified a 5" system and EGS-2 is 6".

This opening is a representation of the East elevation shown on A0313 which clearly indicates the EGS-2 system. Please confirm which system we are to use so that we may revise our drawings accordingly.

Response: Sheet A0313, East elevation at brick/projected window designation of EGS-2 is incorrect. Designation should be EGS-3 (5 in. system per Spec Section 08 44 23, Page 7). Correction will be issued in future addendum. Please revise Sheet M16 to comply with Detail 1-Sheet A0422 in Addendum 1 illustrating the EGS-3 system.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Kathy Williams

Date: June 9, 2016