



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 06, 2016 NO.: RFI-153

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Storm pipe size near A.2-1.6

Response Required By: June 15, 2016

Drawing / Spec Reference:

Information Requested:

On the exterior wall near Column 1.6 and A.2, the primary storm drainage leaves the building. It serves a similar quantity of deck drains as does the parallel overflow drain exiting the angled exterior wall on A-line. The overflow drain line is sized at 6" as it leaves the building, but the primary storm is only called out as a 4" pipe. Please verify the storm pipe sizing at this area on the primary storm.

Response:

The 4" is not correct, the correctly sized pipe will be identified in an up-coming addendum.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mark Davis, David Mason and Associates

Date: June 7, 2016