



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 08, 2016 NO.: RFI-159

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Wiremold data locations

Response Required By: June 15, 2016

Drawing / Spec Reference:

Information Requested:

* Should the Data outlets in room 137 be installed in the Wiremold race way or at 18" no notation is given. (North Wall) **Install data outlets in Wiremold.**

* Should the Data outlet in room 291 be installed in the Wiremold race way or at 18" No notation is given. (West Wall) **Install data outlet in Wiremold.**

* Room 289 A show a data location in wiremold on the south wall... there is no wiremold on this wall. What is the Mounting Height for this Data Outlet since there is no wiremold in this location? **Mount at 18" AFF.**

* Should the Data outlet in room 235 be installed in the Wiremold race way or at 18" No notation is given. (North Wall) **Install the west data outlet in Wiremold, install the east data outlet in the wall between the sink and Coviron Environmental Chamber (09.09.04).**

* Should the Data outlet in room 388 be installed in the Wiremold race way or at 18" No notation is given. (East Wall) **Install data outlet in Wiremold.**

* Should the Data outlet in room 383 be installed in the Wiremold race way or at 18" No notation is given. (South Wall) **Install data outlet in Wiremold.**

Response:

Answered By: _____

Date: _____



ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: _____

Date: _____