



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 13, 2016 NO.: RFI-163

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: twist locks located in floor boxes

Response Required By: June 20, 2016

Drawing / Spec Reference:

Information Requested:

The L5-20R twist lock receptacles will not physically fit in the RFB4S-FC floor boxes, please advise. Correspondence from vendor attached.

Response: Provide 20A duplex receptacles in place of L5-20R twist lock receptacles located in floor boxes. Architect will coordinate with lab furniture manufacturer to provide standard straight blade plug.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: **Bill Shaw**

Date: **07/22/2016**

From: [Gates, Devin](#)
To: [Gates, Devin](#)
Subject: FW: RFB4S-FC-fire classified Webster ISB
Date: Monday, June 13, 2016 7:55:34 AM
Attachments: [image003.png](#)

From: rick.branstetter@geco.com [mailto:rick.branstetter@geco.com]
Sent: Saturday, June 11, 2016 3:17 PM
To: Gates, Devin
Subject: Fwd: RFB4S-FC-fire classified Webster ISB

Here is the email trail



Rick Branstetter
Preconstruction Manager
Phone: 314-678-8053
Main: 314-772-5400
Mobile: 314-280-7477
Fax: 314-678-8353

web:
www.geco.com

3401 Bent Ave
St. Louis, MO
63116
[View Map](#)

E-mail is not necessarily a secure means of communication. The information transmitted herewith is intended only for the person or entity to which it is addressed and contains confidential or privileged material. If you are not the intended recipient of this message, please disregard its contents and destroy the message and its attachments. We also ask that you notify the sender if you have received this message in error. Any improper use of this information is prohibited.

Rick,

As discussed, please provide supporting correspondence or product information from the vender that supports the issue of the twist lock being too deep of a device for the box.

Thanks,

DEVIN GATES
SENIOR PROJECT ENGINEER

Cell: 314-348-8828
Main: 636-561-9500

- - - - -
77 Westport Plaza, Suite 250
St. Louis, MO 63146

- - - - -
PARIC.COM



Please consider your environmental responsibility before printing this e-mail

This e-mail message and any files transmitted with it may be CONFIDENTIAL and are intended for the addressee only. Any unauthorized use, dissemination of the information, or copying of this message is prohibited. If you are not the intended addressee, please notify the sender immediately and delete this message.

Begin forwarded message:

From: "Mark Harbaugh" <markh@fishcorep.com>
Date: June 10, 2016 at 12:42:39 PM CDT
To: "rick.branstetter@geco.com" <rick.branstetter@geco.com>
Subject: FW: RFB4S-FC-fire classified Webster ISB

Hello Houston, we may have a problem....

I mentioned this to you Monday before I formalized the quote, in which I included basic device plates & or blanks because of the descriptions noted on the original spec...., see below, but the bad news is that L5-20R's will not fit in these plates??

Let me know how you want to approach....,

Thnx, Mark.

From: John R Marrotte [<mailto:john.marrotte@legrand.us>] **On Behalf Of** US-WES-SharedMail-custom-eng
Sent: Thursday, June 09, 2016 1:30 PM
To: Mark Harbaugh <markh@fishcorep.com>
Cc: Gary P Denault <gary.denault@legrand.us>
Subject: Re: RFB4S-FC-fire classified

After physical review, we cannot put the twist lock devices using 1.59" dia openings in this plate. The device will interfere with the box.
john Marrotte

From: John R Marrotte on behalf of US-WES-SharedMail-custom-eng

Sent: Wednesday, June 8, 2016 10:43 AM
To: Mark Harbaugh
Cc: Gary P Denault
Subject: Re: RFB4S-FC-fire classified

We have to look at the assembly to see if there is interference. We have not built this part before. Will know today.

From: Mark Harbaugh <markh@fishcorep.com>
Sent: Tuesday, June 7, 2016 11:01 AM
To: US-WES-SharedMail-custom-eng
Subject: FW: RFB4S-FC-fire classified

Good morning..., has anyone had a chance to review this yet?

I need to finalize my quote & need to know if we can provide a device plate for both the RFB2S-FC & the RFB4S-FC that will accept an L5-20R twistlock?

IF so, can you provide a part number for both units & I will send the custom quote to Bev?

Thanks very much..., Mark.

From: Mark Harbaugh
Sent: Monday, June 06, 2016 9:25 AM
To: 'US-WES-SharedMail-Technical-Support' <Technical.Support@legrand.us>
Subject: RE: RFB4S-FC-fire classified

Thanks Gary..., hopefully they come back with a good answer!

Mark.

From: Gary P Denault [<mailto:gary.denault@legrand.us>] **On Behalf Of** US-WES-SharedMail-Technical-Support
Sent: Monday, June 06, 2016 9:22 AM
To: Mark Harbaugh <markh@fishcorep.com>; US-WES-SharedMail-custom-eng <custom.eng-wm@legrand.us>
Subject: Re: RFB4S-FC-fire classified

Good morning Mark,

I don't see an option for either plate. For the blank we can offer the WTB-2-AB with a CM2-BL-GY.

Engineering,

Are we able to offer a custom plate for the RFB4S-FC to accept an L5-20R?

Thanks,

Gary Denault
Legrand | WIREMOLD

Technical Product Support Representative III, Wiremold
ELECTRICAL WIRING SYSTEMS

Legrand, North America
(800) 621-0049 option #3
www.legrand.us

From: Mark Harbaugh <markh@fishcorep.com>

Sent: Monday, June 6, 2016 10:00 AM

To: US-WES-SharedMail-Technical-Support

Subject: RFB4S-FC-fire classified

Good morning..., so I've got a project with quite a few of these boxes, and they are wanting to mount NEMA L5-20 twist locks in these as well as they are asking for blank plates..., and I see neither plate in the cutsheets. What are my options, if any?

Thanks very much, Mark.

Mark Harbaugh
FISHCO GROUP
8721 Mackenzie
St. Louis MO 63123
Cell: 314-277-0911
Fax: 314-865-0051
markh@fishcorep.com

logo-outlines2014



Please check out our new redesigned website celebrating 15 years!

www.fishcorep.com

Ce message, ainsi que tous les fichiers joints à ce message, peuvent contenir des informations sensibles et/ ou confidentielles ne devant pas être divulguées. Si vous n'êtes pas le destinataire de ce message (ou que vous recevez ce message par erreur), nous vous remercions de le notifier immédiatement à son expéditeur, et de détruire ce message. Toute copie, divulgation, modification, utilisation ou diffusion, non autorisée, directe ou indirecte, de tout ou partie de ce message, est strictement interdite.

Se désabonner: Si vous souhaitez être retiré de notre liste de diffusion, s'il vous plaît envoyer vos coordonnées à CASL.unsubscribe@legrand.ca et indiquer quels sont les messages que vous ne souhaitez plus recevoir.

This e-mail, and any document attached hereby, may contain confidential and/or privileged information. If you are not the intended recipient (or have received this e-mail in error) please notify the sender immediately and destroy this e-mail. Any unauthorized, direct or indirect, copying, disclosure, distribution or other use of the material or parts thereof is strictly forbidden.

Unsubscribe: If you would like to be removed from our mailing list, please send your contact information to CASL.unsubscribe@legrand.ca and indicate what messages you no longer wish to receive.

Ce message, ainsi que tous les fichiers joints à ce message, peuvent contenir des informations sensibles et/ ou confidentielles ne devant pas être divulguées. Si vous n'êtes pas le destinataire de ce message (ou que vous recevez ce message par erreur), nous vous remercions de le notifier immédiatement à son expéditeur, et de détruire ce message. Toute copie, divulgation, modification, utilisation ou diffusion, non autorisée, directe ou indirecte, de tout ou partie de ce message, est strictement interdite.

Se désabonner: Si vous souhaitez être retiré de notre liste de diffusion, s'il vous plaît envoyer vos coordonnées à CASL.unsubscribe@legrand.ca et indiquer quels sont les messages que vous ne souhaitez plus recevoir.

This e-mail, and any document attached hereby, may contain confidential and/or privileged information. If you are not the intended recipient (or have received this e-mail in error) please notify the sender immediately and destroy this e-mail. Any unauthorized, direct or indirect, copying, disclosure, distribution or other use of the material or parts thereof is strictly forbidden.

Unsubscribe: If you would like to be removed from our mailing list, please send your contact information to CASL.unsubscribe@legrand.ca and indicate what messages you no longer wish to receive.

Disclaimer

The information contained in this communication from the sender is confidential. It is intended solely for use by the recipient and others authorized to receive it. If you are not the recipient, you are hereby notified that any disclosure, copying, distribution or taking action in relation of the contents of this information is strictly prohibited and may be unlawful.

This email has been scanned for viruses and malware, and may have been automatically archived by **Mimecast Ltd**, an innovator in Software as a Service (SaaS) for business. Providing a **safer** and **more useful** place for your human generated data. Specializing in; Security, archiving and compliance. To find out more [Click Here](#).